CIVIL PRO
AN ISO 9001 : 2008 COMPANY & ACCREDITED LABORATORY AS PER ISO/IEC 17025:2017
# 4, 7TH MAIN MALLESWARAM, BANGALORE -3
Certificate No.: TC-5548

Format No: CP/TF/01

# TEST REPORT OF CEMENT CONCRETE CUBES

ab ID : CP-2022-07-01-01 Date: 19/07/2022

roject Name : Improvements to Roads and Drains at Bharathnagara, Sadiq Layout, Anjanadru Layout Balance Roads and Surrounding Area in Ward No. 06 Byatarayanapura Sub Division

gency : Sri. K Lakshmi Narayana Reddy, No:688, 1st Floor, Vyalikaval Society, Near Chaitanya School, Veeranapalya, Bangalore-560045.

ustomer's Reference : BBMP/EE/BTP/WO/01/2021-22

ate of Receipt : 23-06-2022

ustomer ID : Cement Concrete Pavement - 4th Cross Road

mple Type /Size : 150X150X150 mm

mple grade/Age : M30 / 28 Days Compressive Strength

ference to BIS codes : IS: 516 - 1959 (RA 2018) Methods of Tests for Strength of Concrete Cl.5

te of test : 19/07/2022

| L. o. | Identification Mark | Grade of concrete | Date of Casting | Date of Testing | Dimension of the Specimen (mm) | Cross sectional area (Sq.mm) | Weight of the sample (kg) | Failure Load (KN) | Compressive strength ($N/mm^2$) | Average Compressive Strength ($N/mm^2$) |
|---|---|---|---|---|---|---|---|---|---|---|
| | Cement Concrete Pavement - 4th Cross Road | M30 | 21/06/2022 | 19/07/2022 | 151.58 X 149.32 X 150.08 | 22634 | 8.481 | 762.4 | 33.7 | 32.9 |
| | Cement Concrete Pavement - 4th Cross Road | M30 | 21/06/2022 | 19/07/2022 | 149.39 X 149.19 X 149.79 | 22287 | 8.186 | 713.6 | 32.0 | |
| | Cement Concrete Pavement - 4th Cross Road | M30 | 21/06/2022 | 19/07/2022 | 149.57 X 149.06 X 151.51 | 22295 | 8.205 | 736.4 | 33.0 | |

e results obtained are satisfactory as per standard requirements.

ಸಹಾಯಕ ಅಭಿಯಂತರರು
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ

Assistant Executive Engineer
Byatarayanapura Sub Division
B.B.M P Bangalore-560024

CIVIL Pro Sig..... Date..... BANGALORE

FOR CIVIL Pro.
R. KARTHIK RECHAN
Authorized Signatory
Quality Manager


****End of Report****

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com
HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL | ENVIRONMENTAL
WATER TESTING | GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES

Scanned with CamScanner

CIVIL PRO
AN ISO 9001 : 2008 COMPANY & ACCREDITED LABORATORY AS PER ISO/IEC 17025:2017
# 4, 7TH MAIN MALLESWARAM, BANGALORE -3
Certificate No.: TC-5548

Format No: CP/TF/01

# TEST REPORT OF CEMENT CONCRETE CUBES

: CP-2022-07-01-01 **Date: 28/06/2022**

**Name** : Improvements to Roads and Drains at Bharathnagara, Sadiq Layout, Anjanadru Layout Balance Roads and Surrounding Area in Ward No. 06 Byatarayanapura Sub Division

: Sri. K Lakshmi Narayana Reddy, No:688, 1st Floor, Vyalikaval Society, Near Chaitanya School, Veeranapalya, Bangalore-560045.

**er's Reference** : BBMP/EE/BTP/WO/01/2021-22

**Receipt** : 23-06-2022

**er ID** : Cement Concrete Pavement - 4th Cross Road

**Type /Size** : 150X150X150 mm

**grade/Age** : M30 / 7 Days Compressive Strength

**ıce to BIS codes** : IS: 516 - 1959 (RA 2018) Methods of Tests for Strength of Concrete Cl.5

**test** : 28/06/2022

| Identification Mark | Grade of concrete | Date of Casting | Date of Testing | Dimension of the Specimen (mm) | Cross sectional area (Sq.mm) | Weight of the sample (kg) | Failure Load (KN) | Compressive strength ($N/mm^2$) | Average Compressive Strength ($N/mm^2$) |
|---|---|---|---|---|---|---|---|---|---|
| Cement Concrete Pavement - 4th Cross Road | M30 | 21/06/2022 | 28/06/2022 | 149.05 X 149.54 X 149.66 | 22288 | 9.061 | 563.2 | 25.3 | 25.3 |
| Cement Concrete Pavement - 4th Cross Road | M30 | 21/06/2022 | 28/06/2022 | 151.72 X 149.30 X 151.43 | 22651 | 8.559 | 601.0 | 26.5 | |
| Cement Concrete Pavement - 4th Cross Road | M30 | 21/06/2022 | 28/06/2022 | 150.26 X 151.07 X 151.13 | 22699 | 8.648 | 548.9 | 24.2 | |

esults obtained are satisfactory as per standard requirements.

ಸಹಾಯಕ ಅಭಿಯಂತರರು
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ

Assistant Executive Engineer
Byatarayanapura Sub Division
B.B.M.P Bangalore-560024

CIVIL Pro Sig..... Date..... BANGALORE

FOR CIVIL Pro.
R KARTHIK RECHAN
Authorized Signatory
Quality Manager


****End of Report****

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL | ENVIRONMENTAL
WATER TESTING | GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES

Scanned with CamScanner

CIVIL PRO
AN ISO 9001 : 2008 COMPANY & ACCREDITED LABORATORY AS PER ISO/IEC 17025:2017
# 4, 7TH MAIN MALLESWARAM, BANGALORE -3
Certificate No.: TC-5548

Format No: CP/TF/01

# TEST REPORT OF CEMENT CONCRETE CUBES

b ID : CP-2022-07-01-01 Date: 19/07/2022

oject Name : Improvements to Roads and Drains at Bharathnagara, Sadiq Layout, Anjanadru Layout Balance Roads and Surrounding Area in Ward No. 06 Byatarayanapura Sub Division

ency : Sri. K Lakshmi Narayana Reddy, No:688, 1st Floor, Vyalikaval Society, Near Chaitanya School, Veeranapalya, Bangalore-560045.

stomer's Reference : BBMP/EE/BTP/WO/01/2021-22

te of Receipt : 23-06-2022

stomer ID : Cement Concrete Pavement - 4th Cross Road

mple Type /Size : 150X150X150 mm

mple grade/Age : M30 / 28 Days Compressive Strength

erence to BIS codes : IS: 516 - 1959 (RA 2018) Methods of Tests for Strength of Concrete Cl.5

e of test : 19/07/2022

| | Identification Mark | Grade of concrete | Date of Casting | Date of Testing | Dimension of the Specimen (mm) | Cross sectional area (Sq.mm) | Weight of the sample (kg) | Failure Load (KN) | Compressive strength ($N/mm^2$) | Average Compressive Strength ($N/mm^2$) |
|---|---|---|---|---|---|---|---|---|---|---|
| | Cement Concrete Pavement - 4th Cross Road | M30 | 21/06/2022 | 19/07/2022 | 151.58 X 150.20 X 151.32 | 22767 | 8.508 | 759.9 | 33.4 | 33.1 |
| | Cement Concrete Pavement - 4th Cross Road | M30 | 21/06/2022 | 19/07/2022 | 150.07 X 149.64 X 150.72 | 22456 | 8.590 | 740.6 | 33.0 | |
| | Cement Concrete Pavement - 4th Cross Road | M30 | 21/06/2022 | 19/07/2022 | 151.93 X 151.71 X 150.84 | 23049 | 8.793 | 762.7 | 33.1 | |

e results obtained are satisfactory as per standard requirements.

ಸಹಾಯಕ ಅಭಿಯಂತರರು

Assistant Executive Engineer
Byatarayanapura Sub Division
B.B.M.P. Bangalore-560024

CIVIL Pro Sig..... Date.... BANGALORE

FOR CIVIL Pro.
R KARTHIK RECHAN
Authorized Signatory
Quality Manager

Page 1/1
****End of Report****



Scanned with CamScanner

Format No: CP/TF/01

# TEST REPORT OF CEMENT CONCRETE CUBES

: CP-2022-07-01-01 Date: 30/06/2022

Name : Improvements to Roads and Drains at Bharathnagara, Sadiq Layout, Anjanadru Layout Balance Roads and Surrounding Area in Ward No. 06 Byatarayanapura Sub Division

: Sri. K Lakshmi Narayana Reddy, No:688, 1st Floor, Vyalikaval Society, Near Chaitanya School, Veeranapalya, Bangalore-560045.

ner's Reference : BBMP/EE/BTP/WO/01/2021-22

Receipt : 25-06-2022

ner ID : Cement Concrete Pavement - 5th Cross Road

Type /Size : 150X150X150 mm

grade/Age : M30 / 7 Days Compressive Strength

nce to BIS codes : IS: 516 - 1959 (RA 2018) Methods of Tests for Strength of Concrete Cl.5

f test : 30/06/2022

| Identification Mark | Grade of concrete | Date of Casting | Date of Testing | Dimension of the Specimen (mm) | Cross sectional area (Sq.mm) | Weight of the sample (kg) | Failure Load (KN) | Compressive strength ($N/mm^2$) | Average Compressive Strength ($N/mm^2$) |
|---|---|---|---|---|---|---|---|---|---|
| Cement Concrete Pavement - 5th Cross Road | M30 | 23/06/2022 | 30/06/2022 | 150.91 X 151.73 X 151.56 | 22898 | 8.629 | 594.1 | 25.9 | 25.7 |
| Cement Concrete Pavement - 5th Cross Road | M30 | 23/06/2022 | 30/06/2022 | 150.01 X 149.94 X 151.58 | 22493 | 9.097 | 592.6 | 26.3 | |
| Cement Concrete Pavement - 5th Cross Road | M30 | 23/06/2022 | 30/06/2022 | 149.79 X 151.75 X 149.57 | 22730 | 8.893 | 563.5 | 24.8 | |

results obtained are satisfactory as per standard requirements.

ಸಹಾಯಕ ಅಭಿಯಂತರರು
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ

Assistant Executive Engineer

CIVIL Pro Sig..... Date..... BANGALORE

FOR CIVIL Pro.
R KARTHIK RECHAN
Authorized Signatory
Quality Manager


****End of Report****

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com
HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL | ENVIRONMENTAL
WATER TESTING | GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES

Scanned with CamScanner

CIVIL PRO
AN ISO 9001 : 2008 COMPANY & ACCREDITED LABORATORY AS PER ISO/IEC 17025:2017
# 4, 7TH MAIN MALLESWARAM, BANGALORE -3
Certificate No.: TC-5548

Format No: CP/TF/01

# TEST REPORT OF CEMENT CONCRETE CUBES

Lab ID : CP-2022-07-01-01 Date: 21/07/2022

Project Name : Improvements to Roads and Drains at Bharathnagara, Sadiq Layout, Anjanadru Layout Balance Roads and Surrounding Area in Ward No. 06 Byatarayanapura Sub Division

Agency : Sri. K Lakshmi Narayana Reddy, No:688, 1st Floor, Vyalikaval Society, Near Chaitanya School, Veeranapalya, Bangalore-560045.

Customer's Reference : BBMP/EE/BTP/WO/01/2021-22

Date of Receipt : 25-06-2022

Customer ID : Cement Concrete Pavement - 5th Cross Road

Sample Type /Size : 150X150X150 mm

Sample grade/Age : M30 / 28 Days Compressive Strength

Reference to BIS codes : IS: 516 - 1959 (RA 2018) Methods of Tests for Strength of Concrete Cl.5

Date of test : 21/07/2022

| Sl. No. | Identification Mark | Grade of concrete | Date of Casting | Date of Testing | Dimension of the Specimen (mm) | Cross sectional area (Sq.mm) | Weight of the sample (kg) | Failure Load (KN) | Compressive strength ($N/mm^2$) | Average Compressive Strength ($N/mm^2$) |
|---|---|---|---|---|---|---|---|---|---|---|
| | Cement Concrete Pavement - 5th Cross Road | M30 | 23/06/2022 | 21/07/2022 | 149.44 X 151.67 X 149.04 | 22666 | 8.226 | 761.1 | 33.6 | 33.2 |
| | Cement Concrete Pavement - 5th Cross Road | M30 | 23/06/2022 | 21/07/2022 | 150.65 X 149.83 X 149.34 | 22571 | 8.724 | 730.7 | 32.4 | |
| | Cement Concrete Pavement - 5th Cross Road | M30 | 23/06/2022 | 21/07/2022 | 149.76 X 149.40 X 150.66 | 22375 | 8.768 | 751.4 | 33.6 | |

The results obtained are satisfactory as per standard requirements.

ಸಹಾಯಕ ಅಭಿಯಂತರರು
ಬಿ.ಬಿ.ಎಂ.ಪಿ ವ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ

CIVIL Pro Sig..... Date..... BANGALORE

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

Assistant Executive Engineer
Byatarayanapura Sub Division
BBMP - Bangalore-560024



****End of Report****

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL | ENVIRONMENTAL
WATER TESTING | GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES

Scanned with CamScanner

CIVIL PRO
AN ISO 9001 : 2008 COMPANY & ACCREDITED LABORATORY AS PER ISO/IEC 17025:2017
# 4, 7TH MAIN MALLESWARAM, BANGALORE -3
Certificate No.: TC-5548

Format No: CP/TF/01

# TEST REPORT OF CEMENT CONCRETE CUBES

| | | |
|---|---|---|
| ID | : | CP-2022-07-01-01 **Date: 30/06/2022** |
| ct Name | : | Improvements to Roads and Drains at Bharathnagara, Sadiq Layout, Anjanadru Layout Balance Roads and Surrounding Area in Ward No. 06 Byatarayanapura Sub Division |
| cy | : | Sri. K Lakshmi Narayana Reddy, No:688, 1st Floor, Vyalikaval Society, Near Chaitanya School, Veeranapalya, Bangalore-560045. |
| omer's Reference | : | BBMP/EE/BTP/WO/01/2021-22 |
| of Receipt | : | 25-06-2022 |
| omer ID | : | Cement Concrete Pavement - 5th Cross Road |
| le Type /Size | : | 150X150X150 mm |
| le grade/Age | : | M30 / 7 Days Compressive Strength |
| rence to BIS codes | : | IS: 516 - 1959 (RA 2018) Methods of Tests for Strength of Concrete Cl.5 |
| of test | : | 30/06/2022 |

| Identification Mark | Grade of concrete | Date of Casting | Date of Testing | Dimension of the Specimen (mm) | Cross sectional area (Sq.mm) | Weight of the sample (kg) | Failure Load (KN) | Compressive strength ($N/mm^2$) | Average Compressive Strength ($N/mm^2$) |
|---|---|---|---|---|---|---|---|---|---|
| Cement Concrete Pavement - 5th Cross Road | M30 | 23/06/2022 | 30/06/2022 | 150.10 X 151.38 X 149.17 | 22722 | 8.723 | 585.3 | 25.8 | 25.4 |
| Cement Concrete Pavement - 5th Cross Road | M30 | 23/06/2022 | 30/06/2022 | 150.27 X 150.58 X 150.00 | 22628 | 8.967 | 596.9 | 26.4 | |
| Cement Concrete Pavement - 5th Cross Road | M30 | 23/06/2022 | 30/06/2022 | 151.18 X 151.52 X 149.69 | 22907 | 8.843 | 552.7 | 24.1 | |

results obtained are satisfactory as per standard requirements.

ಸಹಾಯಕ ಅಭಿಯಂತರರು
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ

Assistant Executive Engineer
Byatarayanapura Sub Division
B.B.M.P Bangalore-560024

CIVIL Pro Sig..... Date..... BANGALORE

FOR CIVIL Pro.
R KARTHIK RECHAN
Authorized Signatory
Quality Manager

Page 1/1
****End of Report****



Scanned with CamScanner

CIVIL PRO
AN ISO 9001 : 2008 COMPANY & ACCREDITED LABORATORY AS PER ISO/IEC 17025:2017
# 4, 7TH MAIN MALLESWARAM, BANGALORE -3
Certificate No.: TC-5548

Format No: CP/TF/01

# TEST REPORT OF CEMENT CONCRETE CUBES

ID : CP-2022-07-01-01 Date: 21/07/2022

ect Name : Improvements to Roads and Drains at Bharathnagara, Sadiq Layout, Anjanadru Layout Balance Roads and Surrounding Area in Ward No. 06 Byatarayanapura Sub Division

ıcy : Sri. K Lakshmi Narayana Reddy, No:688, 1st Floor, Vyalikaval Society, Near Chaitanya School, Veeranapalya, Bangalore-560045.

omer's Reference : BBMP/EE/BTP/WO/01/2021-22

of Receipt : 25-06-2022

omer ID : Cement Concrete Pavement - 5th Cross Road

ple Type /Size : 150X150X150 mm

ple grade/Age : M30 / 28 Days Compressive Strength

rence to BIS codes : IS: 516 - 1959 (RA 2018) Methods of Tests for Strength of Concrete Cl.5

of test : 21/07/2022

| Identification Mark | Grade of concrete | Date of Casting | Date of Testing | Dimension of the Specimen (mm) | Cross sectional area (Sq.mm) | Weight of the sample (kg) | Failure Load (KN) | Compressive strength ($N/mm^2$) | Average Compressive Strength ($N/mm^2$) |
|---|---|---|---|---|---|---|---|---|---|
| Cement Concrete Pavement - 5th Cross Road | M30 | 23/06/2022 | 21/07/2022 | 151.80 X 151.12 X 150.74 | 22940 | 9.074 | 766.7 | 33.4 | 32.9 |
| Cement Concrete Pavement - 5th Cross Road | M30 | 23/06/2022 | 21/07/2022 | 151.61 X 149.89 X 149.90 | 22725 | 8.316 | 730.4 | 32.1 | |
| Cement Concrete Pavement - 5th Cross Road | M30 | 23/06/2022 | 21/07/2022 | 151.66 X 151.06 X 150.61 | 22910 | 8.213 | 762.5 | 33.3 | |

results obtained are satisfactory as per standard requirements.

ಸಹಾಯಕ ಅಭಿಯಂತರರು
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬಾಪಿರಾಯನಪುರ ಉಪ ವಿಭಾಗ

Assistant Executive Engineer
Byatarayanapura Sub Division
B.B.M.P Bangalore-560024

CIVIL Pro Sig..... Date..... BANGALORE

FOR CIVIL Pro.
R.KARTHIK RECHAN
Authorized Signatory
Quality Manager

Page 1/1
****End of Report****



Scanned with CamScanner

CIVIL PRO
AN ISO 9001 : 2008 COMPANY & ACCREDITED LABORATORY AS PER ISO/IEC 17025:2017
# 4, 7TH MAIN MALLESWARAM, BANGALORE -3
Certificate No.: TC-5548

Format No: CP/TF/01

# TEST REPORT OF CEMENT CONCRETE CUBES

: CP-2022-07-01-01 **Date: 30/06/2022**

ame : Improvements to Roads and Drains at Bharathnagara, Sadiq Layout, Anjanadru Layout Balance Roads and Surrounding Area in Ward No. 06 Byatarayanapura Sub Division

: Sri. K Lakshmi Narayana Reddy, No:688, 1st Floor, Vyalikaval Society, Near Chaitanya School, Veeranapalya, Bangalore-560045.

r's Reference : BBMP/EE/BTP/WO/01/2021-22

teceipt : 25-06-2022

r ID : Cement Concrete Pavement - 5th Cross Road

Type /Size : 150X150X150 mm

rade/Age : M30 / 7 Days Compressive Strength

e to BIS codes : IS: 516 - 1959 (RA 2018) Methods of Tests for Strength of Concrete Cl.5

est : 30/06/2022

| Identification Mark | Grade of concrete | Date of Casting | Date of Testing | Dimension of the Specimen (mm) | Cross sectional area (Sq.mm) | Weight of the sample (kg) | Failure Load (KN) | Compressive strength (N/mm$^2$) | Average Compressive Strength (N/mm$^2$) |
|---|---|---|---|---|---|---|---|---|---|
| Cement Concrete vement - 5th Cross Road | M30 | 23/06/2022 | 30/06/2022 | 151.73 X 151.29 X 151.41 | 22956 | 8.163 | 578.9 | 25.2 | 25.4 |
| Cement Concrete vement - 5th Cross Road | M30 | 23/06/2022 | 30/06/2022 | 150.81 X 150.66 X 150.52 | 22721 | 9.033 | 608.6 | 26.8 | |
| Cement Concrete vement - 5th Cross Road | M30 | 23/06/2022 | 30/06/2022 | 150.78 X 149.74 X 149.74 | 22579 | 8.577 | 548.1 | 24.3 | |

ults obtained are satisfactory as per standard requirements.

ಸಹಾಯಕ ಅಭಿಯಂತರರು
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ

Assistant Executive Engineer
Byatarayanapura Sub Division
BBMP, Bangalore-560024

CIVIL Pro Sig..... Date..... BANGALORE

FOR CIVIL Pro.
R KARTHIK RECHAN
Authorized Signatory
Quality Manager


****End of Report****

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com
HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL | ENVIRONMENTAL
WATER TESTING | GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES

Scanned with CamScanner

CIVIL PRO
AN ISO 9001 : 2008 COMPANY & ACCREDITED LABORATORY AS PER ISO/IEC 17025:2017
# 4, 7TH MAIN MALLESWARAM, BANGALORE -3
Certificate No.: TC-5548

Format No: CP/TF/01

# TEST REPORT OF CEMENT CONCRETE CUBES

| | | |
|---|---|---|
| D | : | CP-2022-07-01-01 |
| t Name | : | Improvements to Roads and Drains at Bharathnagara, Sadiq Layout, Anjanadru Layout Balance Roads and Surrounding Area in Ward No. 06 Byatarayanapura Sub Division |
| y | : | Sri. K Lakshmi Narayana Reddy, No:688, 1st Floor, Vyalikaval Society, Near Chaitanya School, Veeranapalya, Bangalore-560045. |
| mer's Reference | : | BBMP/EE/BTP/WO/01/2021-22 |
| f Receipt | : | 25-06-2022 |
| mer ID | : | Cement Concrete Pavement - 5th Cross Road |
| le Type /Size | : | 150X150X150 mm |
| le grade/Age | : | M30 / 28 Days Compressive Strength |
| nce to BIS codes | : | IS: 516 - 1959 (RA 2018) Methods of Tests for Strength of Concrete Cl.5 |
| f test | : | 21/07/2022 |

Date: 21/07/2022

| Identification Mark | Grade of concrete | Date of Casting | Date of Testing | Dimension of the Specimen (mm) | Cross sectional area (Sq.mm) | Weight of the sample (kg) | Failure Load (KN) | Compressive strength ($N/mm^2$) | Average Compressive Strength ($N/mm^2$) |
|---|---|---|---|---|---|---|---|---|---|
| Cement Concrete Pavement - 5th Cross Road | M30 | 23/06/2022 | 21/07/2022 | 151.85 X 149.93 X 150.55 | 22766 | 8.799 | 764.1 | 33.6 | 33.2 |
| Cement Concrete Pavement - 5th Cross Road | M30 | 23/06/2022 | 21/07/2022 | 150.09 X 151.62 X 150.03 | 22757 | 8.796 | 746.1 | 32.8 | |
| Cement Concrete Pavement - 5th Cross Road | M30 | 23/06/2022 | 21/07/2022 | 151.03 X 151.25 X 151.55 | 22842 | 8.672 | 757.3 | 33.2 | |

esults obtained are satisfactory as per standard requirements.

ಸಹಾಯಕ ಅಭಿಯಂತರರು
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ

CIVIL Pro Sig..... Date..... BANGALORE

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

Assistant Executive Engineer
Byatarayanapura Sub Division
Bangalore-560024


****End of Report****

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com
HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL | ENVIRONMENTAL
WATER TESTING | GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES

Scanned with CamScanner

CIVIL PRO
AN ISO 9001 : 2008 COMPANY & ACCREDITED LABORATORY AS PER ISO/IEC 17025:2017
# 4, 7TH MAIN MALLESWARAM, BANGALORE -3
Certificate No.: TC-5548

Format No: CP/TF/01

# TEST REPORT OF CEMENT CONCRETE CUBES

: CP-2022-07-01-01 **Date: 30/06/2022**

Name : Improvements to Roads and Drains at Bharathnagara, Sadiq Layout, Anjanadru Layout Balance Roads and Surrounding Area in Ward No. 06 Byatarayanapura Sub Division

: Sri. K Lakshmi Narayana Reddy, No:688, 1st Floor, Vyalikaval Society, Near Chaitanya School, Veeranapalya, Bangalore-560045.

ner's Reference : BBMP/EE/BTP/WO/01/2021-22

f Receipt : 25-06-2022

ner ID : Cement Concrete Pavement - 5th Cross Road

e Type /Size : 150X150X150 mm

e grade/Age : M30 / 7 Days Compressive Strength

nce to BIS codes : IS: 516 - 1959 (RA 2018) Methods of Tests for Strength of Concrete Cl.5

f test : 30/06/2022

| Identification Mark | Grade of concrete | Date of Casting | Date of Testing | Dimension of the Specimen (mm) | Cross sectional area (Sq.mm) | Weight of the sample (kg) | Failure Load (KN) | Compressive strength ($N/mm^2$) | Average Compressive Strength ($N/mm^2$) |
|---|---|---|---|---|---|---|---|---|---|
| Cement Concrete Pavement - 5th Cross Road | M30 | 23/06/2022 | 30/06/2022 | 151.33 X 151.40 X 151.48 | 22911 | 8.711 | 579.5 | 25.3 | 25.5 |
| Cement Concrete Pavement - 5th Cross Road | M30 | 23/06/2022 | 30/06/2022 | 151.19 X 150.37 X 149.39 | 22735 | 8.694 | 599.7 | 26.4 | |
| Cement Concrete Pavement - 5th Cross Road | M30 | 23/06/2022 | 30/06/2022 | 149.04 X 149.11 X 149.47 | 22224 | 8.868 | 555.0 | 25.0 | |

esults obtained are satisfactory as per standard requirements.

ಸಹಾಯಕ ಅಭಿಯಂತರರು
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ

CIVIL Pro Sig..... Date..... BANGALORE

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager



****End of Report****

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL | ENVIRONMENTAL
WATER TESTING | GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES

Scanned with CamScanner

Format No: CP/TF/01

# TEST REPORT OF CEMENT CONCRETE CUBES

| | | |
|---|---|---|
| ID | : | CP-2022-07-01-01 **Date: 21/07/2022** |
| ect Name | : | Improvements to Roads and Drains at Bharathnagara, Sadiq Layout, Anjanadru Layout Balance Roads and Surrounding Area in Ward No. 06 Byatarayanapura Sub Division |
| ıcy | : | Sri. K Lakshmi Narayana Reddy, No:688, 1st Floor, Vyalikaval Society, Near Chaitanya School, Veeranapalya, Bangalore-560045. |
| omer's Reference | : | BBMP/EE/BTP/WO/01/2021-22 |
| of Receipt | : | 25-06-2022 |
| omer ID | : | Cement Concrete Pavement - 5th Cross Road |
| ple Type /Size | : | 150X150X150 mm |
| ple grade/Age | : | M30 / 28 Days Compressive Strength |
| rence to BIS codes | : | IS: 516 - 1959 (RA 2018) Methods of Tests for Strength of Concrete Cl.5 |
| of test | : | 21/07/2022 |

| Identification Mark | Grade of concrete | Date of Casting | Date of Testing | Dimension of the Specimen (mm) | Cross sectional area (Sq.mm) | Weight of the sample (kg) | Failure Load (KN) | Compressive strength ($N/mm^2$) | Average Compressive Strength ($N/mm^2$) |
|---|---|---|---|---|---|---|---|---|---|
| Cement Concrete Pavement - 5th Cross Road | M30 | 23/06/2022 | 21/07/2022 | 149.33 X 151.62 X 150.57 | 22642 | 8.595 | 763.1 | 33.7 | 33.5 |
| Cement Concrete Pavement - 5th Cross Road | M30 | 23/06/2022 | 21/07/2022 | 149.34 X 150.11 X 151.69 | 22417 | 8.389 | 738.0 | 32.9 | |
| Cement Concrete Pavement - 5th Cross Road | M30 | 23/06/2022 | 21/07/2022 | 149.13 X 150.39 X 151.59 | 22427 | 8.292 | 760.2 | 33.9 | |

results obtained are satisfactory as per standard requirements.

ಸಹಾಯಕ ಅಭಿಯಂತರರು
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ

Assistant Executive Engineer

CIVIL Pro Sig..... Date..... BANGALORE

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

Page 1/1
****End of Report****



Scanned with CamScan

Format No: CP/TF/01

# TEST REPORT OF CEMENT CONCRETE CUBES

: CP-2022-07-01-01 **Date: 05/05/2022**

Name : Improvements to Roads and Drains at Bharathnagara, Sadiq Layout, Anjanadru Layout Balance Roads and Surrounding Area in Ward No. 06 Byatarayanapura Sub Division

: Sri. K Lakshmi Narayana Reddy, No:688, 1st Floor, Vyalikaval Society, Near Chaitanya School, Veeranapalya, Bangalore-560045.

ner's Reference : BBMP/EE/BTP/WO/01/2021-22

Receipt : 30-04-2022

ner ID : Drain Bottom Raft - Urdu School Road (Anam Enclave)

Type /Size : 150X150X150 mm

grade/Age : M20 / 7 Days Compressive Strength

nce to BIS codes : IS: 516 - 1959 (RA 2018) Methods of Tests for Strength of Concrete Cl.5

test : 05/05/2022

| Identification Mark | Grade of concrete | Date of Casting | Date of Testing | Dimension of the Specimen (mm) | Cross sectional area (Sq.mm) | Weight of the sample (kg) | Failure Load (KN) | Compressive strength (N/mm²) | Average Compressive Strength (N/mm²) |
|---|---|---|---|---|---|---|---|---|---|
| Drain Bottom Raft - Urdu School Road (Anam Enclave) | M20 | 28/04/2022 | 05/05/2022 | 151.15 X 151.61 X 151.90 | 22917 | 8.566 | 421.8 | 18.4 | 18.5 |
| Drain Bottom Raft - Urdu School Road (Anam Enclave) | M20 | 28/04/2022 | 05/05/2022 | 151.36 X 149.77 X 150.83 | 22668 | 8.932 | 426.1 | 18.8 | |
| Drain Bottom Raft - Urdu School Road (Anam Enclave) | M20 | 28/04/2022 | 05/05/2022 | 150.87 X 149.89 X 150.03 | 22613 | 8.249 | 416.2 | 18.4 | |

esults obtained are satisfactory as per standard requirements.

ಸಹಾಯಕ ಅಭಿಯಂತರರು
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ

CIVIL Pro Sig..... Date..... BANGALORE

FOR CIVIL Pro.
R KARTHIK RECHAN
Authorized Signatory
Quality Manager


****End of Report****

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com
HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL | ENVIRONMENTAL
WATER TESTING | GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES

Scanned with CamScanner

CIVIL PRO
AN ISO 9001 : 2008 COMPANY & ACCREDITED LABORATORY AS PER ISO/IEC 17025:2017
# 4, 7TH MAIN MALLESWARAM, BANGALORE -3
Certificate No.: TC-5548

Format No: CP/TF/01

# TEST REPORT OF CEMENT CONCRETE CUBES

| | | |
|---|---|---|
| D | : | CP-2022-07-01-01 Date: 26/05/2022 |
| ct Name | : | Improvements to Roads and Drains at Bharathnagara, Sadiq Layout, Anjanadru Layout Balance Roads and Surrounding Area in Ward No. 06 Byatarayanapura Sub Division |
| cy | : | Sri. K Lakshmi Narayana Reddy, No:688, 1st Floor, Vyalikaval Society, Near Chaitanya School, Veeranapalya, Bangalore-560045. |
| mer's Reference | : | BBMP/EE/BTP/WO/01/2021-22 |
| of Receipt | : | 30-04-2022 |
| mer ID | : | Drain Bottom Raft - Urdu School Road (Anam Enclave) |
| le Type /Size | : | 150X150X150 mm |
| le grade/Age | : | M20 / 28 Days Compressive Strength |
| ence to BIS codes | : | IS: 516 - 1959 (RA 2018) Methods of Tests for Strength of Concrete Cl.5 |
| of test | : | 26/05/2022 |

| Identification Mark | Grade of concrete | Date of Casting | Date of Testing | Dimension of the Specimen (mm) | Cross sectional area (Sq.mm) | Weight of the sample (kg) | Failure Load (KN) | Compressive strength ($N/mm^2$) | Average Compressive Strength ($N/mm^2$) |
|---|---|---|---|---|---|---|---|---|---|
| Drain Bottom Raft - Urdu School Road (Anam Enclave) | M20 | 28/04/2022 | 26/05/2022 | 149.23 X 150.32 X 150.88 | 22432 | 8.604 | 537.2 | 23.9 | 23.2 |
| Drain Bottom Raft - Urdu School Road (Anam Enclave) | M20 | 28/04/2022 | 26/05/2022 | 151.58 X 150.31 X 151.45 | 22784 | 8.544 | 515.1 | 22.6 | |
| Drain Bottom Raft - Urdu School Road (Anam Enclave) | M20 | 28/04/2022 | 26/05/2022 | 149.59 X 149.71 X 151.93 | 22396 | 8.463 | 517.1 | 23.1 | |

results obtained are satisfactory as per standard requirements.

ಸಹಾಯಕ ಅಭಿಯಂತರರು
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ

Assistant Executive Engineer
Byatarayanapura Sub Division
B.B.M.P Bangalore-560024

FOR CIVIL Pro.
CIVIL Pro Sig..... Date..... BANGALORE
R KARTHIK RECHAN
Authorized Signatory
Quality Manager


****End of Report****

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com
HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL | ENVIRONMENTAL
TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES

Scanned with CamScanner

Format No: CP/TF/01

# TEST REPORT OF CEMENT CONCRETE CUBES

| | | |
|---|---|---|
| | : | CP-2022-07-01-01 Date: 05/05/2022 |
| t Name | : | Improvements to Roads and Drains at Bharathnagara, Sadiq Layout, Anjanadru Layout Balance Roads and Surrounding Area in Ward No. 06 Byatarayanapura Sub Division |
| y | : | Sri. K Lakshmi Narayana Reddy, No:688, 1st Floor, Vyalikaval Society, Near Chaitanya School, Veeranapalya, Bangalore-560045. |
| ner's Reference | : | BBMP/EE/BTP/WO/01/2021-22 |
| f Receipt | : | 30-04-2022 |
| mer ID | : | Drain Bottom Raft - Urdu School Road (Anam Enclave) |
| e Type /Size | : | 150X150X150 mm |
| e grade/Age | : | M20 / 7 Days Compressive Strength |
| nce to BIS codes | : | IS: 516 - 1959 (RA 2018) Methods of Tests for Strength of Concrete Cl.5 |
| f test | : | 05/05/2022 |

| Identification Mark | Grade of concrete | Date of Casting | Date of Testing | Dimension of the Specimen (mm) | Cross sectional area (Sq.mm) | Weight of the sample (kg) | Failure Load (KN) | Compressive strength ($N/mm^2$) | Average Compressive Strength ($N/mm^2$) |
|---|---|---|---|---|---|---|---|---|---|
| Drain Bottom Raft - Urdu School Road (Anam Enclave) | M20 | 28/04/2022 | 05/05/2022 | 150.24 X 149.14 X 151.75 | 22407 | 8.993 | 403.8 | 18.0 | 18.3 |
| Drain Bottom Raft - Urdu School Road (Anam Enclave) | M20 | 28/04/2022 | 05/05/2022 | 149.63 X 150.60 X 150.67 | 22535 | 8.823 | 420.5 | 18.7 | |
| Drain Bottom Raft - Urdu School Road (Anam Enclave) | M20 | 28/04/2022 | 05/05/2022 | 150.69 X 150.80 X 151.64 | 22725 | 8.510 | 414.9 | 18.3 | |

results obtained are satisfactory as per standard requirements.

ಸಹಾಯಕ ಅಭಿಯಂತರರು
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ

Assistant Engineer
Byatarayanapura Sub Division
B.B.M.P Bangalore-560024

CIVIL Pro Sig..... Date..... BANGALORE

FOR CIVIL Pro.
R KARTHIK RECHAN
Authorized Signatory
Quality Manager

Page 1/1
****End of Report****



Scanned with CamScanner

CIVIL PRO
AN ISO 9001 : 2008 COMPANY & ACCREDITED LABORATORY AS PER ISO/IEC 17025:2017
# 4, 7TH MAIN MALLESWARAM, BANGALORE -3

Certificate No.: TC-5548

Format No: CP/TF/01

# TEST REPORT OF CEMENT CONCRETE CUBES

| | | |
|---|---|---|
| ID | : | CP-2022-07-01-01 |
| ect Name | : | Improvements to Roads and Drains at Bharathnagara, Sadiq Layout, Anjanadru Layout Balance Roads and Surrounding Area in Ward No. 06 Byatarayanapura Sub Division |
| ncy | : | Sri. K Lakshmi Narayana Reddy, No:688, 1st Floor, Vyalikaval Society, Near Chaitanya School, Veeranapalya, Bangalore-560045. |
| omer's Reference | : | BBMP/EE/BTP/WO/01/2021-22 |
| of Receipt | : | 30-04-2022 |
| omer ID | : | Drain Bottom Raft - Urdu School Road (Anam Enclave) |
| ple Type /Size | : | 150X150X150 mm |
| ple grade/Age | : | M20 / 28 Days Compressive Strength |
| rence to BIS codes | : | IS: 516 - 1959 (RA 2018) Methods of Tests for Strength of Concrete Cl.5 |
| of test | : | 26/05/2022 |

Date: 26/05/2022

| Identification Mark | Grade of concrete | Date of Casting | Date of Testing | Dimension of the Specimen (mm) | Cross sectional area (Sq.mm) | Weight of the sample (kg) | Failure Load (KN) | Compressive strength ($N/mm^2$) | Average Compressive Strength ($N/mm^2$) |
|---|---|---|---|---|---|---|---|---|---|
| Drain Bottom Raft - Urdu School Road (Anam Enclave) | M20 | 28/04/2022 | 26/05/2022 | 151.21 X 149.22 X 150.83 | 22563 | 8.831 | 526.0 | 23.3 | 23.1 |
| Drain Bottom Raft - Urdu School Road (Anam Enclave) | M20 | 28/04/2022 | 26/05/2022 | 150.97 X 149.36 X 149.00 | 22549 | 9.017 | 504.6 | 22.4 | |
| Drain Bottom Raft - Urdu School Road (Anam Enclave) | M20 | 28/04/2022 | 26/05/2022 | 151.80 X 151.73 X 149.20 | 23032 | 8.918 | 541.1 | 23.5 | |

e results obtained are satisfactory as per standard requirements.

ಸಹಾಯಕ ಅಭಿಯಂತರರು
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ

Assistant Executive Engineer
Byatarayanapura Sub Division
B.B.M.P Bangalore-560026

CIVIL Pro Sig..... Date..... BANGALORE

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager


****End of Report****

civilproexperts@gmail.com

Scanned with CamScanner

CIVIL PRO
AN ISO 9001 : 2008 COMPANY & ACCREDITED LABORATORY AS PER ISO/IEC 17025:2017
# 4, 7TH MAIN MALLESWARAM, BANGALORE -3
Certificate No.: TC-5548

Format No: CP/TF/01

# TEST REPORT OF CEMENT CONCRETE CUBES

| | | |
|---|---|---|
| D | : | CP-2022-07-01-01 **Date: 05/05/2022** |
| ct Name | : | Improvements to Roads and Drains at Bharathnagara, Sadiq Layout, Anjanadru Layout Balance Roads and Surrounding Area in Ward No. 06 Byatarayanapura Sub Division |
| cy | : | Sri. K Lakshmi Narayana Reddy, No:688, 1st Floor, Vyalikaval Society, Near Chaitanya School, Veeranapalya, Bangalore-560045. |
| mer's Reference | : | BBMP/EE/BTP/WO/01/2021-22 |
| of Receipt | : | 30-04-2022 |
| mer ID | : | Drain Bottom Raft - Urdu School Road (Anam Enclave) |
| le Type /Size | : | 150X150X150 mm |
| le grade/Age | : | M20 / 7 Days Compressive Strength |
| ence to BIS codes | : | IS: 516 - 1959 (RA 2018) Methods of Tests for Strength of Concrete Cl.5 |
| of test | : | 05/05/2022 |

| Identification Mark | Grade of concrete | Date of Casting | Date of Testing | Dimension of the Specimen (mm) | Cross sectional area (Sq.mm) | Weight of the sample (kg) | Failure Load (KN) | Compressive strength ($N/mm^2$) | Average Compressive Strength ($N/mm^2$) |
|---|---|---|---|---|---|---|---|---|---|
| Drain Bottom Raft - Urdu School Road (Anam Enclave) | M20 | 28/04/2022 | 05/05/2022 | 151.88 X 150.13 X 151.08 | 22803 | 8.366 | 421.0 | 18.5 | 18.3 |
| Drain Bottom Raft - Urdu School Road (Anam Enclave) | M20 | 28/04/2022 | 05/05/2022 | 151.94 X 150.34 X 150.43 | 22842 | 8.117 | 412.0 | 18.0 | |
| Drain Bottom Raft - Urdu School Road (Anam Enclave) | M20 | 28/04/2022 | 05/05/2022 | 151.86 X 149.26 X 149.62 | 22666 | 8.983 | 415.5 | 18.3 | |

results obtained are satisfactory as per standard requirements.

ಸಹಾಯಕ ಅಭಿಯಂತರರು
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ
Assistant Executive Engineer
Byatarayanapura Sub Division
B.B.M.P.

CIVIL Pro Sig..... Date..... BANGALORE

FOR CIVIL Pro.
R KARTHIK RECHAN
Authorized Signatory
Quality Manager


****End of Report****

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com
STRUCTURAL ENVIRONMENTAL

Scanned with CamScanner

CIVIL PRO
AN ISO 9001 : 2008 COMPANY & ACCREDITED LABORATORY AS PER ISO/IEC 17025:2017
# 4, 7TH MAIN MALLESWARAM, BANGALORE -3

Certificate No.: TC-5548

Format No: CP/TF/01

# TEST REPORT OF CEMENT CONCRETE CUBES

Date: 26/05/2022

| | | |
|---|---|---|
| , ID | : | CP-2022-07-01-01 |
| ject Name | : | Improvements to Roads and Drains at Bharathnagara, Sadiq Layout, Anjanadru Layout Balance Roads and Surrounding Area in Ward No. 06 Byatarayanapura Sub Division |
| ncy | : | Sri. K Lakshmi Narayana Reddy, No:688, 1st Floor, Vyalikaval Society, Near Chaitanya School, Veeranapalya, Bangalore-560045. |
| tomer's Reference | : | BBMP/EE/BTP/WO/01/2021-22 |
| e of Receipt | : | 30-04-2022 |
| tomer ID | : | Drain Bottom Raft - Urdu School Road (Anam Enclave) |
| nple Type /Size | : | 150X150X150 mm |
| nple grade/Age | : | M20 / 28 Days Compressive Strength |
| erence to BIS codes | : | IS: 516 - 1959 (RA 2018) Methods of Tests for Strength of Concrete Cl.5 |
| e of test | : | 26/05/2022 |

| | Identification Mark | Grade of concrete | Date of Casting | Date of Testing | Dimension of the Specimen (mm) | Cross sectional area (Sq.mm) | Weight of the sample (kg) | Failure Load (KN) | Compressive strength ($N/mm^2$) | Average Compressive Strength ($N/mm^2$) |
|---|---|---|---|---|---|---|---|---|---|---|
| | Drain Bottom Raft - Urdu School Road (Anam Enclave) | M20 | 28/04/2022 | 26/05/2022 | 151.99 X 151.52 X 151.92 | 23030 | 9.020 | 551.1 | 23.9 | 23.6 |
| | Drain Bottom Raft - Urdu School Road (Anam Enclave) | M20 | 28/04/2022 | 26/05/2022 | 150.03 X 150.84 X 149.79 | 22631 | 8.343 | 518.7 | 22.9 | |
| | Drain Bottom Raft - Urdu School Road (Anam Enclave) | M20 | 28/04/2022 | 26/05/2022 | 151.18 X 151.21 X 150.48 | 22860 | 8.376 | 548.1 | 24.0 | |

e results obtained are satisfactory as per standard requirements.

ಸಹಾಯಕ ಅಭಿಯಂತರರು
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ

CIVIL Pro Sig..... Date..... BANGALORE

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager



****End of Report****

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL | ENVIRONMENTAL
WATER TESTING | GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES

Scanned with CamScanner

CIVIL PRO
AN ISO 9001 : 2008 COMPANY & ACCREDITED LABORATORY AS PER ISO/IEC 17025:2017
# 4, 7TH MAIN MALLESWARAM, BANGALORE -3

Certificate No.: TC-5548

Format No: CP/TF/01

# TEST REPORT OF CEMENT CONCRETE CUBES

Date: 05/05/2022

| | | |
|---|---|---|
| b ID | : | CP-2022-07-01-01 |
| ject Name | : | Improvements to Roads and Drains at Bharathnagara, Sadiq Layout, Anjanadru Layout Balance Roads and Surrounding Area in Ward No. 06 Byatarayanapura Sub Division |
| ency | : | Sri. K Lakshmi Narayana Reddy, No:688, 1st Floor, Vyalikaval Society, Near Chaitanya School, Veeranapalya, Bangalore-560045. |
| tomer's Reference | : | BBMP/EE/BTP/WO/01/2021-22 |
| e of Receipt | : | 30-04-2022 |
| tomer ID | : | Drain Bottom Raft - Urdu School Road (Anam Enclave) |
| nple Type /Size | : | 150X150X150 mm |
| nple grade/Age | : | M20 / 7 Days Compressive Strength |
| erence to BIS codes | : | IS: 516 - 1959 (RA 2018) Methods of Tests for Strength of Concrete Cl.5 |
| e of test | : | 05/05/2022 |

| Identification Mark | Grade of concrete | Date of Casting | Date of Testing | Dimension of the Specimen (mm) | Cross sectional area (Sq.mm) | Weight of the sample (kg) | Failure Load (KN) | Compressive strength ($N/mm^2$) | Average Compressive Strength ($N/mm^2$) |
|---|---|---|---|---|---|---|---|---|---|
| Drain Bottom Raft - Urdu School Road (Anam Enclave) | M20 | 28/04/2022 | 05/05/2022 | 150.30 X 150.64 X 150.95 | 22642 | 8.311 | 413.7 | 18.3 | 18.3 |
| Drain Bottom Raft - Urdu School Road (Anam Enclave) | M20 | 28/04/2022 | 05/05/2022 | 149.61 X 149.21 X 151.62 | 22324 | 8.998 | 403.4 | 18.1 | |
| Drain Bottom Raft - Urdu School Road (Anam Enclave) | M20 | 28/04/2022 | 05/05/2022 | 150.98 X 150.16 X 149.07 | 22671 | 8.167 | 421.2 | 18.6 | |

: results obtained are satisfactory as per standard requirements.

ಸಹಾಯಕ ಅಭಿಯಂತರರು
ಬಿಬಿಎಂಪಿ ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ

Assistant Engineer
Byatarayanapura Sub Division
B.B.M.P Bangalore-560024

CIVIL Pro Sig..... Date..... BANGALORE

FOR CIVIL Pro.
R KARTHIK RECHAN
Authorized Signatory
Quality Manager

Page 1/1
****End of Report****



Scanned with CamScanner

CIVIL PRO
AN ISO 9001 : 2008 COMPANY & ACCREDITED LABORATORY AS PER ISO/IEC 17025:2017
# 4, 7TH MAIN MALLESWARAM, BANGALORE -3

Certificate No.: TC-5548

Format No: CP/TF/01

# TEST REPORT OF CEMENT CONCRETE CUBES

Date: 26/05/2022

| | | |
|---|---|---|
| ab ID | : | CP-2022-07-01-01 |
| oject Name | : | Improvements to Roads and Drains at Bharathnagara, Sadiq Layout, Anjanadru Layout Balance Roads and Surrounding Area in Ward No. 06 Byatarayanapura Sub Division |
| gency | : | Sri. K Lakshmi Narayana Reddy, No:688, 1st Floor, Vyalikaval Society, Near Chaitanya School, Veeranapalya, Bangalore-560045. |
| stomer's Reference | : | BBMP/EE/BTP/WO/01/2021-22 |
| te of Receipt | : | 30-04-2022 |
| stomer ID | : | Drain Bottom Raft - Urdu School Road (Anam Enclave) |
| mple Type /Size | : | 150X150X150 mm |
| mple grade/Age | : | M20 / 28 Days Compressive Strength |
| ference to BIS codes | : | IS: 516 - 1959 (RA 2018) Methods of Tests for Strength of Concrete Cl.5 |
| te of test | : | 26/05/2022 |

| Sl. No. | Identification Mark | Grade of concrete | Date of Casting | Date of Testing | Dimension of the Specimen (mm) | Cross sectional area (Sq.mm) | Weight of the sample (kg) | Failure Load (KN) | Compressive strength ($N/mm^2$) | Average Compressive Strength ($N/mm^2$) |
|---|---|---|---|---|---|---|---|---|---|---|
| 1 | Drain Bottom Raft - Urdu School Road (Anam Enclave) | M20 | 28/04/2022 | 26/05/2022 | 149.67 X 151.47 X 151.03 | 22670 | 8.907 | 522.9 | 23.1 | 23.2 |
| 2 | Drain Bottom Raft - Urdu School Road (Anam Enclave) | M20 | 28/04/2022 | 26/05/2022 | 151.17 X 149.13 X 149.85 | 22545 | 8.691 | 516.4 | 22.9 | |
| 3 | Drain Bottom Raft - Urdu School Road (Anam Enclave) | M20 | 28/04/2022 | 26/05/2022 | 151.85 X 150.15 X 149.82 | 22801 | 8.484 | 538.6 | 23.6 | |

he results obtained are satisfactory as per standard requirements.

ಸಹಾಯಕ ಅಭಿಯಂತರರು
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ

Assistant Executive Engineer
Byatarayanapura Sub Division
B B M P Bangalore-560024

CIVIL Pro Sig..... Date..... BANGALORE

FOR CIVIL Pro.
R.KARTHIK RECHAN
Authorized Signatory
Quality Manager

Page 1/1
****End of Report****



Scanned with CamScanner

CIVIL PRO
AN ISO 9001 : 2008 COMPANY & ACCREDITED LABORATORY AS PER ISO/IEC 17025:2017
# 4, 7TH MAIN MALLESWARAM, BANGALORE -3
Certificate No.: TC-5548

Format No: CP/TF/01

# TEST REPORT OF CEMENT CONCRETE CUBES

Date: 11/05/2022

: CP-2022-07-01-01

: Improvements to Roads and Drains at Bharathnagara, Sadiq Layout, Anjanadru Layout Balance Roads and Surrounding Area in Ward No. 06 Byatarayanapura Sub Division

: Sri. K Lakshmi Narayana Reddy, No:688, 1st Floor, Vyalikaval Society, Near Chaitanya School, Veeranapalya, Bangalore-560045.

: BBMP/EE/BTP/WO/01/2021-22

: 06-05-2022

: Drain Bottom Raft -Fathima Furniture Opposite Road (Anam Enclave)

: 150X150X150 mm

: M20 / 7 Days Compressive Strength

: IS: 516 - 1959 (RA 2018) Methods of Tests for Strength of Concrete Cl.5

: 11/05/2022

| Identification Mark | Grade of concrete | Date of Casting | Date of Testing | Dimension of the Specimen (mm) | Cross sectional area (Sq.mm) | Weight of the sample (kg) | Failure Load (KN) | Compressive strength ($N/mm^2$) | Average Compressive Strength ($N/mm^2$) |
|---|---|---|---|---|---|---|---|---|---|
| Drain Bottom Raft - Fathima Furniture Opposite Road (Anam Enclave) | M20 | 04/05/2022 | 11/05/2022 | 151.45 X 150.73 X 149.27 | 22829 | 8.411 | 426.7 | 18.7 | 18.6 |
| Drain Bottom Raft - Fathima Furniture Opposite Road (Anam Enclave) | M20 | 04/05/2022 | 11/05/2022 | 150.74 X 150.42 X 150.59 | 22674 | 8.454 | 422.4 | 18.6 | |
| Drain Bottom Raft - Fathima Furniture Opposite Road (Anam Enclave) | M20 | 04/05/2022 | 11/05/2022 | 149.58 X 149.10 X 151.78 | 22303 | 8.843 | 413.8 | 18.6 | |

The results obtained are satisfactory as per standard requirements.

ಸಹಾಯಕ ಅಭಿಯಂತರರು
ಬಿ.ಬಿ.ಎಂ.ಪಿ. ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ

Assistant Executive Engineer
Byatarayanapura Sub Division
B.B.M.P. Bangalore-560024

CIVIL Pro Sig..... Date..... BANGALORE

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager


****End of Report****

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com
HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL | ENVIRONMENTAL
WATER TESTING | GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES

Scanned with CamScanner

CIVIL PRO
AN ISO 9001 : 2008 COMPANY & ACCREDITED LABORATORY AS PER ISO/IEC 17025:2017
# 4, 7TH MAIN MALLESWARAM, BANGALORE -3

Certificate No.: TC-5548

# TEST REPORT OF CEMENT CONCRETE CUBES

Format No: CP/TF/01

Lab ID : CP-2022-07-01-01

Project Name : Improvements to Roads and Drains at Bharathnagara, Sadiq Layout, Anjanadru Layout Balance Roads and Surrounding Area in Ward No. 06 Byatarayanapura Sub Division

Date: 01/06/2022

Agency : Sri. K Lakshmi Narayana Reddy, No:688, 1st Floor, Vyalikaval Society, Near Chaitanya School, Veeranapalya, Bangalore-560045.

Customer's Reference : BBMP/EE/BTP/WO/01/2021-22

Date of Receipt : 06-05-2022

Customer ID : Drain Bottom Raft -Fathima Furniture Opposite Road (Anam Enclave)

Sample Type /Size : 150X150X150 mm

Sample grade/Age : M20 / 28 Days Compressive Strength

Reference to BIS codes : IS: 516 - 1959 (RA 2018) Methods of Tests for Strength of Concrete Cl.5

Date of test : 01/06/2022

| Sl. No. | Identification Mark | Grade of concrete | Date of Casting | Date of Testing | Dimension of the Specimen (mm) | Cross sectional area (Sq.mm) | Weight of the sample (kg) | Failure Load (KN) | Compressive strength ($N/mm^2$) | Average Compressive Strength ($N/mm^2$) |
|---|---|---|---|---|---|---|---|---|---|---|
| | Drain Bottom Raft - Fathima Furniture Opposite Road (Anam Enclave) | M20 | 04/05/2022 | 01/06/2022 | 149.41 X 149.50 X 151.96 | 22336 | 8.773 | 515.2 | 23.1 | 23.0 |
| | Drain Bottom Raft - Fathima Furniture Opposite Road (Anam Enclave) | M20 | 04/05/2022 | 01/06/2022 | 149.49 X 149.55 X 151.58 | 22356 | 8.286 | 492.5 | 22.0 | |
| | Drain Bottom Raft - Fathima Furniture Opposite Road (Anam Enclave) | M20 | 04/05/2022 | 01/06/2022 | 151.10 X 151.14 X 149.39 | 22837 | 8.588 | 543.8 | 23.8 | |

The results obtained are satisfactory as per standard requirements.

ಸಹಾಯಕ ಅಭಿಯಂತರರು
ಬಿ.ಬಿ.ಎಂ.ಪಿ. ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ

Assistant Executive Engineer
BBMP Byatarayanapura Sub Division

FOR CIVIL Pro.

CIVIL Pro Sig..... Date..... BANGALORE

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

Page 1/1

****End of Report****



Scanned with CamScanner

CIVIL PRO
AN ISO 9001 : 2008 COMPANY & ACCREDITED LABORATORY AS PER ISO/IEC 17025:2017
# 4, 7TH MAIN MALLESWARAM, BANGALORE -3

Certificate No.: TC-5548

Format No: CP/TF/01

# TEST REPORT OF CEMENT CONCRETE CUBES

Date: 11/05/2022

| | | |
|---|---|---|
| Lab ID | : | CP-2022-07-01-01 |
| Project Name | : | Improvements to Roads and Drains at Bharathnagara, Sadiq Layout, Anjanadru Layout Balance Roads and Surrounding Area in Ward No. 06 Byatarayanapura Sub Division |
| Agency | : | Sri. K Lakshmi Narayana Reddy, No:688, 1st Floor, Vyalikaval Society, Near Chaitanya School, Veeranapalya, Bangalore-560045. |
| Customer's Reference | : | BBMP/EE/BTP/WO/01/2021-22 |
| Date of Receipt | : | 06-05-2022 |
| Customer ID | : | Drain Bottom Raft -Fathima Furniture Opposite Road (Anam Enclave) |
| Sample Type /Size | : | 150X150X150 mm |
| Sample grade/Age | : | M20 / 7 Days Compressive Strength |
| Reference to BIS codes | : | IS: 516 - 1959 (RA 2018) Methods of Tests for Strength of Concrete Cl.5 |
| Date of test | : | 11/05/2022 |

| Sl. No. | Identification Mark | Grade of concrete | Date of Casting | Date of Testing | Dimension of the Specimen (mm) | Cross sectional area (Sq.mm) | Weight of the sample (kg) | Failure Load (KN) | Compressive strength ($N/mm^2$) | Average Compressive Strength ($N/mm^2$) |
|---|---|---|---|---|---|---|---|---|---|---|
| 1 | Drain Bottom Raft - Fathima Furniture Opposite Road (Anam Enclave) | M20 | 04/05/2022 | 11/05/2022 | 151.11 X 151.11 X 150.72 | 22834 | 8.305 | 415.9 | 18.2 | 18.6 |
| 2 | Drain Bottom Raft - Fathima Furniture Opposite Road (Anam Enclave) | M20 | 04/05/2022 | 11/05/2022 | 149.90 X 149.10 X 149.50 | 22351 | 8.672 | 418.8 | 18.7 | |
| 3 | Drain Bottom Raft - Fathima Furniture Opposite Road (Anam Enclave) | M20 | 04/05/2022 | 11/05/2022 | 149.10 X 150.99 X 150.58 | 22514 | 8.373 | 422.2 | 18.8 | |

The results obtained are satisfactory as per standard requirements.

ಸಹಾಯಕ ಅಭಿಯಂತರರು
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ

Assistant Executive Engineer
Byatarayanapura Sub Division
B.B.M.P Bangalore-560024

CIVIL Pro Sig..... Date..... BANGALORE

FOR CIVIL Pro
R KARTHIK RECHAN
Authorized Signatory
Quality Manager


****End of Report****

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com
HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL | ENVIRONMENTAL
WATER TESTING | GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES

Scanned with CamScanner

CIVIL PRO
AN ISO 9001 : 2008 COMPANY & ACCREDITED LABORATORY AS PER ISO/IEC 17025:2017
# 4, 7TH MAIN MALLESWARAM, BANGALORE -3

Certificate No.: TC-5548

# TEST REPORT OF CEMENT CONCRETE CUBES

Format No: CP/TF/01

Lab ID : CP-2022-07-01-01

Project Name : Improvements to Roads and Drains at Bharathnagara, Sadiq Layout, Anjanadru Layout Balance Roads and Surrounding Area in Ward No. 06 Byatarayanapura Sub Division

Date: 01/06/2022

Agency : Sri. K Lakshmi Narayana Reddy, No:688, 1st Floor, Vyalikaval Society, Near Chaitanya School, Veeranapalya, Bangalore-560045.

Customer's Reference : BBMP/EE/BTP/WO/01/2021-22

Date of Receipt : 06-05-2022

Customer ID : Drain Bottom Raft -Fathima Furniture Opposite Road (Anam Enclave)

Sample Type /Size : 150X150X150 mm

Sample grade/Age : M20 / 28 Days Compressive Strength

Reference to BIS codes : IS: 516 - 1959 (RA 2018) Methods of Tests for Strength of Concrete Cl.5

Date of test : 01/06/2022

| Sl. No. | Identification Mark | Grade of concrete | Date of Casting | Date of Testing | Dimension of the Specimen (mm) | Cross sectional area (Sq.mm) | Weight of the sample (kg) | Failure Load (KN) | Compressive strength ($N/mm^2$) | Average Compressive Strength ($N/mm^2$) |
|---|---|---|---|---|---|---|---|---|---|---|
| 1 | Drain Bottom Raft - Fathima Furniture Opposite Road (Anam Enclave) | M20 | 04/05/2022 | 01/06/2022 | 149.09 X 151.28 X 151.57 | 22554 | 9.039 | 536.5 | 23.8 | 23.4 |
| 2 | Drain Bottom Raft - Fathima Furniture Opposite Road (Anam Enclave) | M20 | 04/05/2022 | 01/06/2022 | 149.18 X 150.85 X 150.60 | 22503 | 8.537 | 513.9 | 22.8 | |
| 3 | Drain Bottom Raft - Fathima Furniture Opposite Road (Anam Enclave) | M20 | 04/05/2022 | 01/06/2022 | 150.38 X 150.09 X 149.23 | 22569 | 8.195 | 530.2 | 23.5 | |

The results obtained are satisfactory as per standard requirements.

ಸಹಾಯಕ ಅಭಿಯಂತರರು
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ

Assistant Executive Engineer
Byatarayanapura Sub Division
B.B.M.P Bangalore-560024

CIVIL Pro Sig..... Date..... BANGALORE

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

Page 1/1
****End of Report****



Scanned with CamScanner

CIVIL PRO
AN ISO 9001 : 2008 COMPANY & ACCREDITED LABORATORY AS PER ISO/IEC 17025:2017
# 4, 7TH MAIN MALLESWARAM, BANGALORE -3

Certificate No.: TC-5548

# TEST REPORT OF CEMENT CONCRETE CUBES

Format No: CP/TF/01

Date: 11/05/2022

| | | |
|---|---|---|
| b ID | : | CP-2022-07-01-01 |
| oject Name | : | Improvements to Roads and Drains at Bharathnagara, Sadiq Layout, Anjanadru Layout Balance Roads and Surrounding Area in Ward No. 06 Byatarayanapura Sub Division |
| ency | : | Sri. K Lakshmi Narayana Reddy, No:688, 1st Floor, Vyalikaval Society, Near Chaitanya School, Veeranapalya, Bangalore-560045. |
| stomer's Reference | : | BBMP/EE/BTP/WO/01/2021-22 |
| te of Receipt | : | 06-05-2022 |
| stomer ID | : | Drain Bottom Raft -Fathima Furniture Opposite Road (Anam Enclave) |
| mple Type /Size | : | 150X150X150 mm |
| mple grade/Age | : | M20 / 7 Days Compressive Strength |
| ference to BIS codes | : | IS: 516 - 1959 (RA 2018) Methods of Tests for Strength of Concrete Cl.5 |
| te of test | : | 11/05/2022 |

| S. No. | Identification Mark | Grade of concrete | Date of Casting | Date of Testing | Dimension of the Specimen (mm) | Cross sectional area (Sq.mm) | Weight of the sample (kg) | Failure Load (KN) | Compressive strength ($N/mm^2$) | Average Compressive Strength ($N/mm^2$) |
|---|---|---|---|---|---|---|---|---|---|---|
| 1 | Drain Bottom Raft - Fathima Furniture Opposite Road (Anam Enclave) | M20 | 04/05/2022 | 11/05/2022 | 151.22 X 151.52 X 151.14 | 22912 | 8.806 | 421.9 | 18.4 | 18.3 |
| 2 | Drain Bottom Raft - Fathima Furniture Opposite Road (Anam Enclave) | M20 | 04/05/2022 | 11/05/2022 | 150.03 X 151.39 X 149.44 | 22713 | 8.433 | 420.0 | 18.5 | |
| 3 | Drain Bottom Raft - Fathima Furniture Opposite Road (Anam Enclave) | M20 | 04/05/2022 | 11/05/2022 | 151.85 X 151.21 X 150.17 | 22961 | 8.261 | 413.9 | 18.0 | |

The results obtained are satisfactory as per standard requirements.

ಸಹಾಯಕ ಕಾರ್ಯನಿರ್ವಾಹಕ ಅಭಿಯಂತರರು
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ

Assistant Executive Engineer
Byatarayanapura Sub Division
B.B.M.P Bangalore-560024

CIVIL Pro Sig..... Date..... BANGALORE

FOR CIVIL Pro.
R.KARTHIK RECHAN
Authorized Signatory
Quality Manager

Page 1/1
****End of Report****



Scanned with CamScanner

CIVIL PRO
AN ISO 9001 : 2008 COMPANY & ACCREDITED LABORATORY AS PER ISO/IEC 17025:2017
# 4, 7TH MAIN MALLESWARAM, BANGALORE -3

Certificate No.: TC-5548

# TEST REPORT OF CEMENT CONCRETE CUBES

Format No: CP/TF/01

Lab ID : CP-2022-07-01-01

Project Name : Improvements to Roads and Drains at Bharathnagara, Sadiq Layout, Anjanadru Layout Balance Roads and Surrounding Area in Ward No. 06 Byatarayanapura Sub Division

Date: 01/06/2022

Agency : Sri. K Lakshmi Narayana Reddy, No:688, 1st Floor, Vyalikaval Society, Near Chaitanya School, Veeranapalya, Bangalore-560045.

Customer's Reference : BBMP/EE/BTP/WO/01/2021-22

Date of Receipt : 06-05-2022

Customer ID : Drain Bottom Raft -Fathima Furniture Opposite Road (Anam Enclave)

Sample Type /Size : 150X150X150 mm

Sample grade/Age : M20 / 28 Days Compressive Strength

Reference to BIS codes : IS: 516 - 1959 (RA 2018) Methods of Tests for Strength of Concrete Cl.5

Date of test : 01/06/2022

| Sl. No. | Identification Mark | Grade of concrete | Date of Casting | Date of Testing | Dimension of the Specimen (mm) | Cross sectional area (Sq.mm) | Weight of the sample (kg) | Failure Load (KN) | Compressive strength ($N/mm^2$) | Average Compressive Strength ($N/mm^2$) |
|---|---|---|---|---|---|---|---|---|---|---|
| 1 | Drain Bottom Raft - Fathima Furniture Opposite Road (Anam Enclave) | M20 | 04/05/2022 | 01/06/2022 | 150.75 X 151.41 X 151.76 | 22825 | 8.781 | 535.2 | 23.4 | 23.3 |
| 2 | Drain Bottom Raft - Fathima Furniture Opposite Road (Anam Enclave) | M20 | 04/05/2022 | 01/06/2022 | 150.86 X 149.72 X 149.12 | 22588 | 8.968 | 518.3 | 22.9 | |
| 3 | Drain Bottom Raft - Fathima Furniture Opposite Road (Anam Enclave) | M20 | 04/05/2022 | 01/06/2022 | 151.71 X 150.24 X 150.32 | 22792 | 8.265 | 534.0 | 23.4 | |

The results obtained are satisfactory as per standard requirements.

ಸಹಾಯಕ ಅಭಿಯಂತರರು
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ

Assistant Executive Engineer
Byatarayanapura Sub Division
B.B.M.P Bangalore-560024

CIVIL Pro Sig..... Date..... BANGALORE

FOR CIVIL Pro.
R KARTHIK RECHAN
Authorized Signatory
Quality Manager

Page 1/1
****End of Report****



Scanned with CamScanner

CIVIL PRO
AN ISO 9001 : 2008 COMPANY & ACCREDITED LABORATORY AS PER ISO/IEC 17025:2017
# 4, 7TH MAIN MALLESWARAM, BANGALORE -3

Certificate No.: TC-5548

# TEST REPORT OF CEMENT CONCRETE CUBES

Format No: CP/TF/01

Date: 11/05/2022

| | | |
|---|---|---|
| Lab ID | : | CP-2022-07-01-01 |
| Project Name | : | Improvements to Roads and Drains at Bharathnagara, Sadiq Layout, Anjanadru Layout Balance Roads and Surrounding Area in Ward No. 06 Byatarayanapura Sub Division |
| Agency | : | Sri. K Lakshmi Narayana Reddy, No:688, 1st Floor, Vyalikaval Society, Near Chaitanya School, Veeranapalya, Bangalore-560045. |
| Customer's Reference | : | BBMP/EE/BTP/WO/01/2021-22 |
| Date of Receipt | : | 06-05-2022 |
| Customer ID | : | Drain Bottom Raft -Fathima Furniture Opposite Road (Anam Enclave) |
| Sample Type /Size | : | 150X150X150 mm |
| Sample grade/Age | : | M20 / 7 Days Compressive Strength |
| Reference to BIS codes | : | IS: 516 - 1959 (RA 2018) Methods of Tests for Strength of Concrete Cl.5 |
| Date of test | : | 11/05/2022 |

| Sl. No. | Identification Mark | Grade of concrete | Date of Casting | Date of Testing | Dimension of the Specimen (mm) | Cross sectional area (Sq.mm) | Weight of the sample (kg) | Failure Load (KN) | Compressive strength ($N/mm^2$) | Average Compressive Strength ($N/mm^2$) |
|---|---|---|---|---|---|---|---|---|---|---|
| 1 | Drain Bottom Raft - Fathima Furniture Opposite Road (Anam Enclave) | M20 | 04/05/2022 | 11/05/2022 | 149.68 X 150.40 X 150.00 | 22512 | 8.451 | 417.1 | 18.5 | 18.7 |
| 2 | Drain Bottom Raft - Fathima Furniture Opposite Road (Anam Enclave) | M20 | 04/05/2022 | 11/05/2022 | 149.35 X 151.30 X 149.71 | 22597 | 8.470 | 422.5 | 18.7 | |
| 3 | Drain Bottom Raft - Fathima Furniture Opposite Road (Anam Enclave) | M20 | 04/05/2022 | 11/05/2022 | 150.37 X 151.23 X 151.40 | 22741 | 8.895 | 428.1 | 18.8 | |

The results obtained are satisfactory as per standard requirements.

ಸಹಾಯಕ ಅಭಿಯಂತರರು
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ

Assistant Executive Engineer
Byatarayanapura Sub Division
B.B.M.P. Bangalore-560024

CIVIL Pro Sig..... Date..... BANGALORE

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager



****End of Report****

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL | ENVIRONMENTAL
WATER TESTING | GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES

Scanned with CamScanner

# TEST REPORT OF CEMENT CONCRETE CUBES

Format No: CP/TF/01

Lab ID : CP-2022-07-01-01

Project Name : Improvements to Roads and Drains at Bharathnagara, Sadiq Layout, Anjanadru Layout Balance Roads and Surrounding Area in Ward No. 06 Byatarayanapura Sub Division

Date: 01/06/2022

Agency : Sri. K Lakshmi Narayana Reddy, No:688, 1st Floor, Vyalikaval Society, Near Chaitanya School, Veeranapalya, Bangalore-560045.

Customer's Reference : BBMP/EE/BTP/WO/01/2021-22

Date of Receipt : 06-05-2022

Customer ID : Drain Bottom Raft -Fathima Furniture Opposite Road (Anam Enclave)

Sample Type /Size : 150X150X150 mm

Sample grade/Age : M20 / 28 Days Compressive Strength

Reference to BIS codes : IS: 516 - 1959 (RA 2018) Methods of Tests for Strength of Concrete Cl.5

Date of test : 01/06/2022

| Sl. No. | Identification Mark | Grade of concrete | Date of Casting | Date of Testing | Dimension of the Specimen (mm) | Cross sectional area (Sq.mm) | Weight of the sample (kg) | Failure Load (KN) | Compressive strength ($N/mm^2$) | Average Compressive Strength ($N/mm^2$) |
|---|---|---|---|---|---|---|---|---|---|---|
| 1 | Drain Bottom Raft - Fathima Furniture Opposite Road (Anam Enclave) | M20 | 04/05/2022 | 01/06/2022 | 151.12 X 150.31 X 150.66 | 22715 | 8.485 | 542.0 | 23.9 | 23.1 |
| 2 | Drain Bottom Raft - Fathima Furniture Opposite Road (Anam Enclave) | M20 | 04/05/2022 | 01/06/2022 | 149.62 X 149.34 X 149.48 | 22344 | 8.979 | 492.1 | 22.0 | |
| 3 | Drain Bottom Raft - Fathima Furniture Opposite Road (Anam Enclave) | M20 | 04/05/2022 | 01/06/2022 | 149.68 X 150.86 X 149.95 | 22581 | 8.476 | 528.6 | 23.4 | |

The results obtained are satisfactory as per standard requirements.

ಸಹಾಯಕ ಅಭಿಯಂತರರು
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ

CIVIL Pro Sig..... Date..... BANGALORE

FOR CIVIL Pro.

R.KARTHIK RECHAN
Authorized Signatory
Quality Manager

Assistant Executive Engineer
Byatarayanapura Sub Division
B.B.M.P. Bangalore-560024

Page 1/1

****End of Report****



Scanned with CamScanner

CIVIL PRO
AN ISO 9001 : 2008 COMPANY & ACCREDITED LABORATORY AS PER ISO/IEC 17025:2017
# 4, 7TH MAIN MALLESWARAM, BANGALORE -3

Certificate No.: TC-5548

Format No: CP/TF/01

# TEST REPORT OF CEMENT CONCRETE CUBES

Date: 17/05/2022

Lab ID : CP-2022-07-01-01
Project Name : Improvements to Roads and Drains at Bharathnagara, Sadiq Layout, Anjanadru Layout Balance Roads and Surrounding Area in Ward No. 06 Byatarayanapura Sub Division
Agency : Sri. K Lakshmi Narayana Reddy, No:688, 1st Floor, Vyalikaval Society, Near Chaitanya School, Veeranapalya, Bangalore-560045.
Customer's Reference : BBMP/EE/BTP/WO/01/2021-22
Date of Receipt : 12-05-2022
Customer ID : Drain Bottom Raft -Fathima Furniture Beside Road (Anam Enclave)
Sample Type /Size : 150X150X150 mm
Sample grade/Age : M20 / 7 Days Compressive Strength
Reference to BIS codes : IS: 516 - 1959 (RA 2018) Methods of Tests for Strength of Concrete Cl.5
Date of test : 17/05/2022

| Sl. No. | Identification Mark | Grade of concrete | Date of Casting | Date of Testing | Dimension of the Specimen (mm) | Cross sectional area (Sq.mm) | Weight of the sample (kg) | Failure Load (KN) | Compressive strength ($N/mm^2$) | Average Compressive Strength ($N/mm^2$) |
|---|---|---|---|---|---|---|---|---|---|---|
| 1 | Drain Bottom Raft - Fathima Furniture Beside Road (Anam Enclave) | M20 | 10/05/2022 | 17/05/2022 | 150.12 X 151.10 X 149.45 | 22684 | 8.347 | 415.6 | 18.3 | 18.6 |
| 2 | Drain Bottom Raft - Fathima Furniture Beside Road (Anam Enclave) | M20 | 10/05/2022 | 17/05/2022 | 149.33 X 151.09 X 149.44 | 22562 | 8.838 | 423.6 | 18.8 | |
| 3 | Drain Bottom Raft - Fathima Furniture Beside Road (Anam Enclave) | M20 | 10/05/2022 | 17/05/2022 | 149.74 X 149.43 X 149.99 | 22376 | 8.704 | 421.1 | 18.8 | |

* The results obtained are satisfactory as per standard requirements.

ಸಹಾಯಕ ಅಭಿಯಂತರರು
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ

Assistant Executive Engineer
Byatarayanapura Sub Division
B.B.M.P Bangalore-560024

CIVIL Pro Sig..... Date..... BANGALORE

FOR CIVIL Pro.
R KARTHIK RECHAN
Authorized Signatory
Quality Manager

Page 1/1
****End of Report****



Scanned with CamScanner

CIVIL PRO
AN ISO 9001 : 2008 COMPANY & ACCREDITED LABORATORY AS PER ISO/IEC 17025:2017
# 4, 7TH MAIN MALLESWARAM, BANGALORE -3

Certificate No.: TC-5548

# TEST REPORT OF CEMENT CONCRETE CUBES

Format No: CP/TF/01

Lab ID : CP-2022-07-01-01

Project Name : Improvements to Roads and Drains at Bharathnagara, Sadiq Layout, Anjanadru Layout Balance Roads and Surrounding Area in Ward No. 06 Byatarayanapura Sub Division

Date: 07/06/2022

Agency : Sri. K Lakshmi Narayana Reddy, No:688, 1st Floor, Vyalikaval Society, Near Chaitanya School, Veeranapalya, Bangalore-560045.

Customer's Reference : BBMP/EE/BTP/WO/01/2021-22

Date of Receipt : 12-05-2022

Customer ID : Drain Bottom Raft -Fathima Furniture Beside Road (Anam Enclave)

Sample Type /Size : 150X150X150 mm

Sample grade/Age : M20 / 28 Days Compressive Strength

Reference to BIS codes : IS: 516 - 1959 (RA 2018) Methods of Tests for Strength of Concrete Cl.5

Date of test : 07/06/2022

| Sl. No. | Identification Mark | Grade of concrete | Date of Casting | Date of Testing | Dimension of the Specimen (mm) | Cross sectional area (Sq.mm) | Weight of the sample (kg) | Failure Load (KN) | Compressive strength ($N/mm^2$) | Average Compressive Strength ($N/mm^2$) |
|---|---|---|---|---|---|---|---|---|---|---|
| 1 | Drain Bottom Raft - Fathima Furniture Beside Road (Anam Enclave) | M20 | 10/05/2022 | 07/06/2022 | 150.96 X 151.67 X 151.44 | 22896 | 8.673 | 540.3 | 23.6 | 23.3 |
| 2 | Drain Bottom Raft - Fathima Furniture Beside Road (Anam Enclave) | M20 | 10/05/2022 | 07/06/2022 | 151.13 X 150.56 X 151.06 | 22755 | 8.153 | 515.5 | 22.7 | |
| 3 | Drain Bottom Raft - Fathima Furniture Beside Road (Anam Enclave) | M20 | 10/05/2022 | 07/06/2022 | 150.50 X 149.11 X 150.41 | 22442 | 8.859 | 528.8 | 23.6 | |

The results obtained are satisfactory as per standard requirements.

ಸಹಾಯಕ ಅಭಿಯಂತರರು
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ

Assistant Executive Engineer
Byatarayanapura Sub Division
B.B.M.P Bangalore-560024

CIVIL Pro Sig..... Date..... BANGALORE

FOR CIVIL Pro.
K KARTHIK RECHAN
Authorized Signatory
Quality Manager

Page 1/1
****End of Report****



Scanned with CamScanner

CIVIL PRO
AN ISO 9001 : 2008 COMPANY & ACCREDITED LABORATORY AS PER ISO/IEC 17025:2017
# 4, 7TH MAIN MALLESWARAM, BANGALORE -3

Certificate No.: TC-5548

# TEST REPORT OF CEMENT CONCRETE CUBES

Format No: CP/TF/01

Lab ID : CP-2022-07-01-01

Project Name : Improvements to Roads and Drains at Bharathnagara, Sadiq Layout, Anjanadru Layout Balance Roads and Surrounding Area in Ward No. 06 Byatarayanapura Sub Division

Date: 17/05/2022

Agency : Sri. K Lakshmi Narayana Reddy, No:688, 1st Floor, Vyalikaval Society, Near Chaitanya School, Veeranapalya, Bangalore-560045.

Customer's Reference : BBMP/EE/BTP/WO/01/2021-22

Date of Receipt : 12-05-2022

Customer ID : Drain Bottom Raft -Fathima Furniture Beside Road (Anam Enclave)

Sample Type /Size : 150X150X150 mm

Sample grade/Age : M20 / 7 Days Compressive Strength

Reference to BIS codes : IS: 516 - 1959 (RA 2018) Methods of Tests for Strength of Concrete Cl.5

Date of test : 17/05/2022

| Sl. No | Identification Mark | Grade of concrete | Date of Casting | Date of Testing | Dimension of the Specimen (mm) | Cross sectional area (Sq.mm) | Weight of the sample (kg) | Failure Load (KN) | Compressive strength ($N/mm^2$) | Average Compressive Strength ($N/mm^2$) |
|---|---|---|---|---|---|---|---|---|---|---|
| 1 | Drain Bottom Raft - Fathima Furniture Beside Road (Anam Enclave) | M20 | 10/05/2022 | 17/05/2022 | 151.34 X 150.23 X 150.07 | 22736 | 8.984 | 431.5 | 19.0 | 18.7 |
| 2 | Drain Bottom Raft - Fathima Furniture Beside Road (Anam Enclave) | M20 | 10/05/2022 | 17/05/2022 | 150.43 X 151.83 X 149.49 | 22840 | 8.308 | 423.3 | 18.5 | |
| 3 | Drain Bottom Raft - Fathima Furniture Beside Road (Anam Enclave) | M20 | 10/05/2022 | 17/05/2022 | 151.45 X 151.91 X 149.87 | 23007 | 8.356 | 430.8 | 18.7 | |

The results obtained are satisfactory as per standard requirements.

ಸಹಾಯಕ ಅಭಿಯಂತರರು
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ

Assistant Executive Engineer
Byatarayanpura Sub Division
B.B.M.P. Bangalore-560024

CIVIL Pro
Sig.....
Date.....
BANGALORE

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

Page 1/1
****End of Report****

M: 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo...
HIGHWAY & BUILDING

Scanned with CamScanner

CIVIL PRO
AN ISO 9001 : 2008 COMPANY & ACCREDITED LABORATORY AS PER ISO/IEC 17025:2017
# 4, 7TH MAIN MALLESWARAM, BANGALORE -3

Certificate No.: TC-5548

# TEST REPORT OF CEMENT CONCRETE CUBES

Format No: CP/TF/01

Date: 07/06/2022

: CP-2022-07-01-01

Sample ID

Name of Work : Improvements to Roads and Drains at Bharathnagara, Sadiq Layout, Anjanadru Layout Balance Roads and Surrounding Area in Ward No. 06 Byatarayanapura Sub Division

Agency : Sri. K Lakshmi Narayana Reddy, No:688, 1st Floor, Vyalikaval Society, Near Chaitanya School, Veeranapalya, Bangalore-560045.

Customer's Reference : BBMP/EE/BTP/WO/01/2021-22

Date of Receipt : 12-05-2022

Customer ID : Drain Bottom Raft -Fathima Furniture Beside Road (Anam Enclave)

Sample Type /Size : 150X150X150 mm

Mix grade/Age : M20 / 28 Days Compressive Strength

Reference to BIS codes : IS: 516 - 1959 (RA 2018) Methods of Tests for Strength of Concrete Cl.5

Date of test : 07/06/2022

| Identification Mark | Grade of concrete | Date of Casting | Date of Testing | Dimension of the Specimen (mm) | Cross sectional area (Sq.mm) | Weight of the sample (kg) | Failure Load (KN) | Compressive strength ($N/mm^2$) | Average Compressive Strength ($N/mm^2$) |
|---|---|---|---|---|---|---|---|---|---|
| Drain Bottom Raft - Fathima Furniture Beside Road (Anam Enclave) | M20 | 10/05/2022 | 07/06/2022 | 149.15 X 150.23 X 150.54 | 22406 | 8.248 | 517.6 | 23.1 | 22.9 |
| Drain Bottom Raft - Fathima Furniture Beside Road (Anam Enclave) | M20 | 10/05/2022 | 07/06/2022 | 149.74 X 151.08 X 150.64 | 22622 | 8.371 | 510.1 | 22.5 | |
| Drain Bottom Raft - Fathima Furniture Beside Road (Anam Enclave) | M20 | 10/05/2022 | 07/06/2022 | 149.80 X 151.81 X 149.42 | 22742 | 8.228 | 523.7 | 23.0 | |

Results obtained are satisfactory as per standard requirements.

ಸಹಾಯಕ ಅಭಿಯಂತರರು
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ

Assistant Executive Engineer
Byatarayanapura Sub Division
B.B.M.P Bangalore-560026

CIVIL Pro Sig..... Date..... BANGALORE

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

Page 1/1

****End of Report****



Scanned with CamScanner

CIVIL PRO
AN ISO 9001 : 2008 COMPANY & ACCREDITED LABORATORY AS PER ISO/IEC 17025:2017
# 4, 7TH MAIN MALLESWARAM, BANGALORE -3

Certificate No.: TC-5548

# TEST REPORT OF CEMENT CONCRETE CUBES

Format No: CP/TF/01

Lab ID : CP-2022-07-01-01

Project Name : Improvements to Roads and Drains at Bharathnagara, Sadiq Layout, Anjanadru Layout Balance Roads and Surrounding Area in Ward No. 06 Byatarayanapura Sub Division

Date: 17/05/2022

Agency : Sri. K Lakshmi Narayana Reddy, No:688, 1st Floor, Vyalikaval Society, Near Chaitanya School, Veeranapalya, Bangalore-560045.

Customer's Reference : BBMP/EE/BTP/WO/01/2021-22

Date of Receipt : 12-05-2022

Customer ID : Drain Bottom Raft -Fathima Furniture Beside Road (Anam Enclave)

Sample Type /Size : 150X150X150 mm

Sample grade/Age : M20 / 7 Days Compressive Strength

Reference to BIS codes : IS: 516 - 1959 (RA 2018) Methods of Tests for Strength of Concrete Cl.5

Date of test : 17/05/2022

| Sl. No. | Identification Mark | Grade of concrete | Date of Casting | Date of Testing | Dimension of the Specimen (mm) | Cross sectional area (Sq.mm) | Weight of the sample (kg) | Failure Load (KN) | Compressive strength ($N/mm^2$) | Average Compressive Strength ($N/mm^2$) |
|---|---|---|---|---|---|---|---|---|---|---|
| 1 | Drain Bottom Raft - Fathima Furniture Beside Road (Anam Enclave) | M20 | 10/05/2022 | 17/05/2022 | 151.84 X 149.51 X 151.87 | 22701 | 8.529 | 414.1 | 18.2 | 18.1 |
| 2 | Drain Bottom Raft - Fathima Furniture Beside Road (Anam Enclave) | M20 | 10/05/2022 | 17/05/2022 | 149.73 X 151.41 X 149.72 | 22670 | 8.202 | 409.2 | 18.0 | |
| 3 | Drain Bottom Raft - Fathima Furniture Beside Road (Anam Enclave) | M20 | 10/05/2022 | 17/05/2022 | 150.33 X 150.89 X 151.52 | 22684 | 8.226 | 410.0 | 18.1 | |

The results obtained are satisfactory as per standard requirements.

ಸಹಾಯಕ ಅಭಿಯಂತರರು
ಬಿಬಿಎಂಪಿ ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ

Assistant Engineer
Byatarayanapura Sub Division
B.B.M.P Bangalore-560024

CIVIL Pro Sig..... Date..... BANGALORE

FOR CIVIL Pro.
R KARTHIK RECHAN
Authorized Signatory
Quality Manager

Page 1/1
****End of Report****



Scanned with CamScanner

CIVIL PRO
AN ISO 9001 : 2008 COMPANY & ACCREDITED LABORATORY AS PER ISO/IEC 17025:2017
# 4, 7TH MAIN MALLESWARAM, BANGALORE -3

Certificate No.: TC-5548

Format No: CP/TF/01

# TEST REPORT OF CEMENT CONCRETE CUBES

Date: 07/06/2022

| | | |
|---|---|---|
| Lab ID | : | CP-2022-07-01-01 |
| Project Name | : | Improvements to Roads and Drains at Bharathnagara, Sadiq Layout, Anjanadru Layout Balance Roads and Surrounding Area in Ward No. 06 Byatarayanapura Sub Division |
| Owner | : | Sri. K Lakshmi Narayana Reddy, No:688, 1st Floor, Vyalikaval Society, Near Chaitanya School, Veeranapalya, Bangalore-560045. |
| Engineer's Reference | : | BBMP/EE/BTP/WO/01/2021-22 |
| Date of Receipt | : | 12-05-2022 |
| Engineer ID | : | Drain Bottom Raft -Fathima Furniture Beside Road (Anam Enclave) |
| Sample Type /Size | : | 150X150X150 mm |
| Concrete grade/Age | : | M20 / 28 Days Compressive Strength |
| Reference to BIS codes | : | IS: 516 - 1959 (RA 2018) Methods of Tests for Strength of Concrete Cl.5 |
| Date of test | : | 07/06/2022 |

| Identification Mark | Grade of concrete | Date of Casting | Date of Testing | Dimension of the Specimen (mm) | Cross sectional area (Sq.mm) | Weight of the sample (kg) | Failure Load (KN) | Compressive strength ($N/mm^2$) | Average Compressive Strength ($N/mm^2$) |
|---|---|---|---|---|---|---|---|---|---|
| Drain Bottom Raft - Fathima Furniture Beside Road (Anam Enclave) | M20 | 10/05/2022 | 07/06/2022 | 151.57 X 149.01 X 149.96 | 22586 | 8.895 | 529.1 | 23.4 | 23.1 |
| Drain Bottom Raft - Fathima Furniture Beside Road (Anam Enclave) | M20 | 10/05/2022 | 07/06/2022 | 151.26 X 151.78 X 150.06 | 22959 | 8.408 | 519.3 | 22.6 | |
| Drain Bottom Raft - Fathima Furniture Beside Road (Anam Enclave) | M20 | 10/05/2022 | 07/06/2022 | 150.94 X 150.40 X 151.41 | 22701 | 8.840 | 526.1 | 23.2 | |

Results obtained are satisfactory as per standard requirements.

ಸಹಾಯಕ ಅಭಿಯಂತರರು
ಬಿಬಿಎಂಪಿ ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ

CIVIL Pro Sig..... Date..... BANGALORE

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

Assistant Executive Engineer
Byatarayanapura Sub Division
B.B.M.P Bangalore-560024



****End of Report****

9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL | ENVIRONMENTAL MANAGEMENT | SURVEYING SERVICES

Scanned with CamScanner

CIVIL PRO
AN ISO 9001 : 2008 COMPANY & ACCREDITED LABORATORY AS PER ISO/IEC 17025:2017
# 4, 7TH MAIN MALLESWARAM, BANGALORE -3

Certificate No.: TC-5548

# TEST REPORT OF CEMENT CONCRETE CUBES

Format No: CP/TF/01

: CP-2022-07-01-01

: Improvements to Roads and Drains at Bharathnagara, Sadiq Layout, Anjanadru Layout Balance Roads and Surrounding Area in Ward No. 06 Byatarayanapura Sub Division

Date: 17/05/2022

: Sri. K Lakshmi Narayana Reddy, No:688, 1st Floor, Vyalikaval Society, Near Chaitanya School, Veeranapalya, Bangalore-560045.

: BBMP/EE/BTP/WO/01/2021-22

: 12-05-2022

: Drain Bottom Raft -Fathima Furniture Beside Road (Anam Enclave)

: 150X150X150 mm

: M20 / 7 Days Compressive Strength

: IS: 516 - 1959 (RA 2018) Methods of Tests for Strength of Concrete Cl.5

: 17/05/2022

| Identification Mark | Grade of concrete | Date of Casting | Date of Testing | Dimension of the Specimen (mm) | Cross sectional area (Sq.mm) | Weight of the sample (kg) | Failure Load (KN) | Compressive strength ($N/mm^2$) | Average Compressive Strength ($N/mm^2$) |
|---|---|---|---|---|---|---|---|---|---|
| Drain Bottom Raft - Fathima Furniture Beside Road (Anam Enclave) | M20 | 10/05/2022 | 17/05/2022 | 149.23 X 150.83 X 150.09 | 22509 | 8.147 | 412.9 | 18.3 | 18.3 |
| Drain Bottom Raft - Fathima Furniture Beside Road (Anam Enclave) | M20 | 10/05/2022 | 17/05/2022 | 151.48 X 150.92 X 150.83 | 22862 | 9.053 | 418.3 | 18.3 | |
| Drain Bottom Raft - Fathima Furniture Beside Road (Anam Enclave) | M20 | 10/05/2022 | 17/05/2022 | 150.61 X 151.30 X 149.21 | 22787 | 8.341 | 418.8 | 18.4 | |

The results obtained are satisfactory as per standard requirements.

ಸಹಾಯಕ ಅಭಿಯಂತರರು
ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ

Assistant Executive Engineer
Byatarayanapura Sub Division
B.B.M.P Bangalore-560026

CIVIL Pro Sig..... Date..... BANGALORE

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

Page 1/1

****End of Report****

: 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com



Scanned with CamScanner

CIVIL PRO
AN ISO 9001 : 2008 COMPANY & ACCREDITED LABORATORY AS PER ISO/IEC 17025:2017
# 4, 7TH MAIN MALLESWARAM, BANGALORE -3

Certificate No.: TC-5548

# TEST REPORT OF CEMENT CONCRETE CUBES

Format No: CP/TF/01

Date: 07/06/2022

: CP-2022-07-01-01

: Improvements to Roads and Drains at Bharathnagara, Sadiq Layout, Anjanadru Layout Balance Roads and Surrounding Area in Ward No. 06 Byatarayanapura Sub Division

: Sri. K Lakshmi Narayana Reddy, No:688, 1st Floor, Vyalikaval Society, Near Chaitanya School, Veeranapalya, Bangalore-560045.

: BBMP/EE/BTP/WO/01/2021-22

: 12-05-2022

: Drain Bottom Raft -Fathima Furniture Beside Road (Anam Enclave)

: 150X150X150 mm

: M20 / 28 Days Compressive Strength

: IS: 516 - 1959 (RA 2018) Methods of Tests for Strength of Concrete Cl.5

: 07/06/2022

| Identification Mark | Grade of concrete | Date of Casting | Date of Testing | Dimension of the Specimen (mm) | Cross sectional area (Sq.mm) | Weight of the sample (kg) | Failure Load (KN) | Compressive strength ($N/mm^2$) | Average Compressive Strength ($N/mm^2$) |
|---|---|---|---|---|---|---|---|---|---|
| Drain Bottom Raft - Fathima Furniture Beside Road (Anam Enclave) | M20 | 10/05/2022 | 07/06/2022 | 151.36 X 151.13 X 149.23 | 22874 | 8.649 | 529.4 | 23.1 | 23.1 |
| Drain Bottom Raft - Fathima Furniture Beside Road (Anam Enclave) | M20 | 10/05/2022 | 07/06/2022 | 151.73 X 150.22 X 149.47 | 22793 | 8.516 | 519.9 | 22.8 | |
| Drain Bottom Raft - Fathima Furniture Beside Road (Anam Enclave) | M20 | 10/05/2022 | 07/06/2022 | 149.81 X 149.76 X 149.40 | 22436 | 9.044 | 523.1 | 23.3 | |

Results obtained are satisfactory as per standard requirements.

ಸಹಾಯಕ ಅಭಿಯಂತರರು
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ

CIVIL Pro Sig..... Date..... BANGALORE

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

Assistant Executive Engineer
Byatarayanapura Sub Division
B.B.M.P Bangalore



****End of Report****

9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL | ENVIRONMENTAL
WATER TESTING | GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES

Scanned with CamScanner

CIVIL PRO
AN ISO 9001 : 2008 COMPANY & ACCREDITED LABORATORY AS PER ISO/IEC 17025:2017
# 4, 7TH MAIN MALLESWARAM, BANGALORE -3

Certificate No.: TC-5548

# TEST REPORT OF CEMENT CONCRETE CUBES

Format No: CP/TF/01

: CP-2022-07-01-01

Date: 23/05/2022

: Improvements to Roads and Drains at Bharathnagara, Sadiq Layout, Anjanadru Layout Balance Roads and Surrounding Area in Ward No. 06 Byatarayanapura Sub Division

: Sri. K Lakshmi Narayana Reddy, No:688, 1st Floor, Vyalikaval Society, Near Chaitanya School, Veeranapalya, Bangalore-560045.

: BBMP/EE/BTP/WO/01/2021-22

: 18-05-2022

: Drain Bottom Raft - 4th Cross Road (Chikkanna Layout)

: 150X150X150 mm

: M20 / 7 Days Compressive Strength

: IS: 516 - 1959 (RA 2018) Methods of Tests for Strength of Concrete Cl.5

: 23/05/2022

| Identification Mark | Grade of concrete | Date of Casting | Date of Testing | Dimension of the Specimen (mm) | Cross sectional area (Sq.mm) | Weight of the sample (kg) | Failure Load (KN) | Compressive strength ($N/mm^2$) | Average Compressive Strength ($N/mm^2$) |
|---|---|---|---|---|---|---|---|---|---|
| Drain Bottom Raft - 4th Cross Road (Chikkanna Layout) | M20 | 16/05/2022 | 23/05/2022 | 149.54 X 150.39 X 151.58 | 22490 | 8.238 | 423.2 | 18.8 | 18.4 |
| Drain Bottom Raft - 4th Cross Road (Chikkanna Layout) | M20 | 16/05/2022 | 23/05/2022 | 149.49 X 151.03 X 149.68 | 22577 | 8.237 | 410.7 | 18.2 | |
| Drain Bottom Raft - 4th Cross Road (Chikkanna Layout) | M20 | 16/05/2022 | 23/05/2022 | 149.28 X 150.36 X 149.14 | 22447 | 8.510 | 405.7 | 18.1 | |

Results obtained are satisfactory as per standard requirements.

ಸಹಾಯಕ ಅಧಿಕಾರಿಗಳು
ಬಿಬಿಎಂಪಿ ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ

CIVIL Pro Sig..... Date..... BANGALORE

FOR CIVIL Pro.
R.KARTHIK RECHAN
Authorized Signatory
Quality Manager

Assistant Executive Engineer
Byatarayanapura Sub Division
B.B.M.P Bangalore-560 026

Page 1/1

****End of Report****



Scanned with CamScanner

CIVIL PRO
AN ISO 9001 : 2008 COMPANY & ACCREDITED LABORATORY AS PER ISO/IEC 17025:2017
# 4, 7TH MAIN MALLESWARAM, BANGALORE -3

Certificate No.: TC-5548

# TEST REPORT OF CEMENT CONCRETE CUBES

Format No: CP/TF/01

: CP-2022-07-01-01

: Improvements to Roads and Drains at Bharathnagara, Sadiq Layout, Anjanadru Layout Balance Roads and Surrounding Area in Ward No. 06 Byatarayanapura Sub Division

Date: 13/06/2022

: Sri. K Lakshmi Narayana Reddy, No:688, 1st Floor, Vyalikaval Society, Near Chaitanya School, Veeranapalya, Bangalore-560045.

: BBMP/EE/BTP/WO/01/2021-22

: 18-05-2022

: Drain Bottom Raft - 4th Cross Road (Chikkanna Layout)

: 150X150X150 mm

: M20 / 28 Days Compressive Strength

: IS: 516 - 1959 (RA 2018) Methods of Tests for Strength of Concrete Cl.5

: 13/06/2022

| Identification Mark | Grade of concrete | Date of Casting | Date of Testing | Dimension of the Specimen (mm) | Cross sectional area (Sq.mm) | Weight of the sample (kg) | Failure Load (KN) | Compressive strength ($N/mm^2$) | Average Compressive Strength ($N/mm^2$) |
|---|---|---|---|---|---|---|---|---|---|
| Drain Bottom Raft - 4th Cross Road (Chikkanna Layout) | M20 | 16/05/2022 | 13/06/2022 | 151.59 X 150.79 X 149.68 | 22858 | 8.436 | 543.6 | 23.8 | 23.3 |
| Drain Bottom Raft - 4th Cross Road (Chikkanna Layout) | M20 | 16/05/2022 | 13/06/2022 | 149.56 X 150.31 X 150.85 | 22479 | 8.644 | 511.7 | 22.8 | |
| Drain Bottom Raft - 4th Cross Road (Chikkanna Layout) | M20 | 16/05/2022 | 13/06/2022 | 150.84 X 151.23 X 150.05 | 22812 | 8.970 | 536.0 | 23.5 | |

sults obtained are satisfactory as per standard requirements.

ಸಹಾಯಕ ಅಭಿಯಂತರರು

Assistant Executive Engineer
Byatarayanapura Sub Division
B.B.M.P Bangalore-560024

CIVIL Pro Sig..... Date..... BANGALORE

FOR CIVIL Pro.
R KARTHIK RECHAN
Authorized Signatory
Quality Manager

Page 1/1

****End of Report****

: 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL | ENVIRONMENTAL
WATER TESTING | GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES

Scanned with CamScanner

Format No: CP/TF/01

# TEST REPORT OF CEMENT CONCRETE CUBES

CP-2022-07-01-01 Date: 23/05/2022

: Improvements to Roads and Drains at Bharathnagara, Sadiq Layout, Anjanadru Layout Balance Roads and Surrounding Area in Ward No. 06 Byatarayanapura Sub Division

: Sri. K Lakshmi Narayana Reddy, No:688, 1st Floor, Vyalikaval Society, Near Chaitanya School, Veeranapalya, Bangalore-560045.

: BBMP/EE/BTP/WO/01/2021-22

: 18-05-2022

: Drain Bottom Raft - 4th Cross Road (Chikkanna Layout)

: 150X150X150 mm

: M20 / 7 Days Compressive Strength

: IS: 516 - 1959 (RA 2018) Methods of Tests for Strength of Concrete Cl.5

: 23/05/2022

| Identification Mark | Grade of concrete | Date of Casting | Date of Testing | Dimension of the Specimen (mm) | Cross sectional area (Sq.mm) | Weight of the sample (kg) | Failure Load (KN) | Compressive strength ($N/mm^2$) | Average Compressive Strength ($N/mm^2$) |
|---|---|---|---|---|---|---|---|---|---|
| rain Bottom Raft - 4th Cross Road Chikkanna Layout) | M20 | 16/05/2022 | 23/05/2022 | 149.11 X 151.86 X 150.34 | 22644 | 8.565 | 413.6 | 18.3 | 18.6 |
| ain Bottom Raft - th Cross Road ikkanna Layout) | M20 | 16/05/2022 | 23/05/2022 | 149.53 X 149.31 X 150.81 | 22326 | 8.988 | 415.4 | 18.6 | |
| n Bottom Raft - h Cross Road kkanna Layout) | M20 | 16/05/2022 | 23/05/2022 | 150.00 X 150.99 X 149.42 | 22649 | 8.408 | 429.0 | 18.9 | |

obtained are satisfactory as per standard requirements.

ಸಹಾಯಕ ಅಭಿಯಂತರರು
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ

Assistant Executive Engineer
Byatarayanapura Sub Division
B.B.M.P Bangalore-560024

CIVIL Pro Sig..... Date..... BANGALORE

FOR CIVIL Pro.
K KARTHIK RECHAN
Authorized Signatory
Quality Manager


****End of Report****

24526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com
Y & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL | ENVIRONMENTAL
R TESTING | GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES
Scanned with CamScanner

CIVIL PRO
AN ISO 9001 : 2008 COMPANY & ACCREDITED LABORATORY AS PER ISO/IEC 17025:2017
# 4, 7TH MAIN MALLESWARAM, BANGALORE -3

Certificate No.: TC-5548

# TEST REPORT OF CEMENT CONCRETE CUBES

Format No: CP/TF/01

: CP-2022-07-01-01

: Improvements to Roads and Drains at Bharathnagara, Sadiq Layout, Anjanadru Layout Balance Roads and Surrounding Area in Ward No. 06 Byatarayanapura Sub Division

Date: 09/05/2022

: Sri. K Lakshmi Narayana Reddy, No:688, 1st Floor, Vyalikaval Society, Near Chaitanya School, Veeranapalya, Bangalore-560045.

: BBMP/EE/BTP/WO/01/2021-22

: 04-05-2022

: Drain Side Wall - Urdu School Road (Anam Enclave)

: 150X150X150 mm

: M20 / 7 Days Compressive Strength

: IS: 516 - 1959 (RA 2018) Methods of Tests for Strength of Concrete Cl.5

: 08/05/2022

| Identification Mark | Grade of concrete | Date of Casting | Date of Testing | Dimension of the Specimen (mm) | Cross sectional area (Sq.mm) | Weight of the sample (kg) | Failure Load (KN) | Compressive strength ($N/mm^2$) | Average Compressive Strength ($N/mm^2$) |
|---|---|---|---|---|---|---|---|---|---|
| Drain Side Wall - Urdu School Road (Anam Enclave) | M20 | 01/05/2022 | 08/05/2022 | 150.09 X 149.50 X 151.62 | 22438 | 8.988 | 426.2 | 19.0 | 18.6 |
| Drain Side Wall - Urdu School Road (Anam Enclave) | M20 | 01/05/2022 | 08/05/2022 | 151.15 X 151.16 X 149.91 | 22849 | 8.541 | 421.0 | 18.4 | |
| Drain Side Wall - Urdu School Road (Anam Enclave) | M20 | 01/05/2022 | 08/05/2022 | 150.59 X 150.46 X 151.53 | 22658 | 9.044 | 413.7 | 18.3 | |

Results obtained are satisfactory as per standard requirements.

ಸಹಾಯಕ ಅಭಿಯಂತರರು
Assistant Executive Engineer
Byatarayanapura Sub Division
B.B.M.P Bangalore-560024

CIVIL Pro Sig..... Date..... BANGALORE

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

Page 1/1

****End of Report****



Scanned with CamScanner

CIVIL PRO
AN ISO 9001 : 2008 COMPANY & ACCREDITED LABORATORY AS PER ISO/IEC 17025:2017
# 4, 7TH MAIN MALLESWARAM, BANGALORE -3

Certificate No.: TC-5548

# TEST REPORT OF CEMENT CONCRETE CUBES

Format No: CP/TF/01

: CP-2022-07-01-01

: Improvements to Roads and Drains at Bharathnagara, Sadiq Layout, Anjanadru Layout Balance Roads and Surrounding Area in Ward No. 06 Byatarayanapura Sub Division

Date: 30/05/2022

: Sri. K Lakshmi Narayana Reddy, No:688, 1st Floor, Vyalikaval Society, Near Chaitanya School, Veeranapalya, Bangalore-560045.

: BBMP/EE/BTP/WO/01/2021-22

: 04-05-2022

: Drain Side Wall - Urdu School Road (Anam Enclave)

: 150X150X150 mm

: M20 / 28 Days Compressive Strength

: IS: 516 - 1959 (RA 2018) Methods of Tests for Strength of Concrete Cl.5

: 29/05/2022

| Identification Mark | Grade of concrete | Date of Casting | Date of Testing | Dimension of the Specimen (mm) | Cross sectional area (Sq.mm) | Weight of the sample (kg) | Failure Load (KN) | Compressive strength (N/mm$^2$) | Average Compressive Strength (N/mm$^2$) |
|---|---|---|---|---|---|---|---|---|---|
| Side Wall - School Road Enclave) | M20 | 01/05/2022 | 29/05/2022 | 151.00 X 149.91 X 151.07 | 22637 | 8.180 | 530.8 | 23.5 | 23.4 |
| Side Wall - School Road Enclave) | M20 | 01/05/2022 | 29/05/2022 | 150.08 X 151.39 X 151.31 | 22721 | 8.169 | 518.1 | 22.8 | |
| Side Wall - School Road Enclave) | M20 | 01/05/2022 | 29/05/2022 | 151.48 X 149.21 X 149.46 | 22603 | 8.902 | 541.9 | 24.0 | |

obtained are satisfactory as per standard requirements.

ಸಹಾಯಕ ಅಭಿಯಂತರರು
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ

Assistant Executive Engineer
Byatarayanapura Sub Division
B.B.M.P Bangalore-560024

CIVIL Pro Sig..... Date..... BANGALORE

FOR CIVIL Pro.
R KARTHIK RECHAN
Authorized Signatory
Quality Manager

Page 1/1
****End of Report****



Scanned with CamScanner

CIVIL PRO
AN ISO 9001 : 2008 COMPANY & ACCREDITED LABORATORY AS PER ISO/IEC 17025:2017
# 4, 7TH MAIN MALLESWARAM, BANGALORE -3

Certificate No.: TC-5548

# TEST REPORT OF CEMENT CONCRETE CUBES

Format No: CP/TF/01

: CP-2022-07-01-01

: Improvements to Roads and Drains at Bharathnagara, Sadiq Layout, Anjanadru Layout Balance Roads and Surrounding Area in Ward No. 06 Byatarayanapura Sub Division

Date: 04/06/2022

: Sri. K Lakshmi Narayana Reddy, No:688, 1st Floor, Vyalikaval Society, Near Chaitanya School, Veeranapalya, Bangalore-560045.

: BBMP/EE/BTP/WO/01/2021-22

: 09-05-2022

: Drain Side Wall - Fathima Furniture Opposite Road (Anam Enclave)

: 150X150X150 mm

: M20 / 28 Days Compressive Strength

: IS: 516 - 1959 (RA 2018) Methods of Tests for Strength of Concrete Cl.5

: 04/06/2022

| Identification Mark | Grade of concrete | Date of Casting | Date of Testing | Dimension of the Specimen (mm) | Cross sectional area (Sq.mm) | Weight of the sample (kg) | Failure Load (KN) | Compressive strength ($N/mm^2$) | Average Compressive Strength ($N/mm^2$) |
|---|---|---|---|---|---|---|---|---|---|
| Drain Side Wall - Fathima Furniture Opposite Road (Anam Enclave) | M20 | 07/05/2022 | 04/06/2022 | 151.92 X 151.85 X 151.23 | 23070 | 8.971 | 544.5 | 23.6 | 23.3 |
| Drain Side Wall - Fathima Furniture Opposite Road (Anam Enclave) | M20 | 07/05/2022 | 04/06/2022 | 151.56 X 150.33 X 151.55 | 22784 | 8.561 | 508.4 | 22.3 | |
| Drain Side Wall - Fathima Furniture Opposite Road (Anam Enclave) | M20 | 07/05/2022 | 04/06/2022 | 149.97 X 149.55 X 150.05 | 22427 | 8.541 | 537.2 | 24.0 | |

Results obtained are satisfactory as per standard requirements.

ಸಹಾಯಕ ಅಭಿಯಂತರರು
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ

Assistant Executive Engineer
Byatarayanapura Sub Division
B.B.M.P Bangalore-560024

CIVIL Pro
Sig.....
Date.....
BANGALORE

FOR CIVIL Pro.
R KARTHIK RECHAN
Authorized Signatory
Quality Manager



****End of Report****

9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL | ENVIRONMENTAL
WATER TESTING | GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES

Scanned with CamScanner

CIVIL PRO
AN ISO 9001 : 2008 COMPANY & ACCREDITED LABORATORY AS PER ISO/IEC 17025:2017
# 4, 7TH MAIN MALLESWARAM, BANGALORE -3

Certificate No.: TC-5548

# TEST REPORT OF CEMENT CONCRETE CUBES

Format No: CP/TF/01

: CP-2022-07-01-01

: Improvements to Roads and Drains at Bharathnagara, Sadiq Layout, Anjanadru Layout Balance Roads and Surrounding Area in Ward No. 06 Byatarayanapura Sub Division — Date: 04/06/2022

: Sri. K Lakshmi Narayana Reddy, No:688, 1st Floor, Vyalikaval Society, Near Chaitanya School, Veeranapalya, Bangalore-560045.

: BBMP/EE/BTP/WO/01/2021-22

Reference : 09-05-2022

: Drain Side Wall - Fathima Furniture Opposite Road (Anam Enclave)

: 150X150X150 mm

Size : M20 / 28 Days Compressive Strength

Age : IS: 516 - 1959 (RA 2018) Methods of Tests for Strength of Concrete Cl.5

BIS codes : 04/06/2022

| Identification Mark | Grade of concrete | Date of Casting | Date of Testing | Dimension of the Specimen (mm) | Cross sectional area (Sq.mm) | Weight of the sample (kg) | Failure Load (KN) | Compressive strength ($N/mm^2$) | Average Compressive Strength ($N/mm^2$) |
|---|---|---|---|---|---|---|---|---|---|
| Side Wall - ma Furniture posite Road am Enclave) | M20 | 07/05/2022 | 04/06/2022 | 150.23 X 151.95 X 151.18 | 22827 | 9.084 | 528.8 | 23.2 | 23.1 |
| Side Wall - ma Furniture posite Road am Enclave) | M20 | 07/05/2022 | 04/06/2022 | 150.67 X 150.99 X 151.24 | 22750 | 9.061 | 502.7 | 22.1 | |
| Side Wall - ma Furniture posite Road am Enclave) | M20 | 07/05/2022 | 04/06/2022 | 151.32 X 150.50 X 149.69 | 22773 | 8.937 | 545.2 | 23.9 | |

obtained are satisfactory as per standard requirements.

ಸಹಾಯಕ ಅಭಿಯಂತರರು
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ

Assistant Executive Engineer
Byatarayanapura Sub Division
B.B.M.P Bangalore

CIVIL Pro Sig..... Date..... BANGALORE

FOR CIVIL Pro.,
R KARTHIK RECHAN
Authorized Signatory
Quality Manager

Page 1/1

****End of Report****



Scanned with CamScanner

CIVIL PRO
AN ISO 9001 : 2008 COMPANY & ACCREDITED LABORATORY AS PER ISO/IEC 17025:2017
# 4, 7TH MAIN MALLESWARAM, BANGALORE -3

Certificate No.: TC-5548

# TEST REPORT OF CEMENT CONCRETE CUBES

Format No: CP/TF/01

CP-2022-07-01-01

Date: 14/05/2022

: Improvements to Roads and Drains at Bharathnagara, Sadiq Layout, Anjanadru Layout Balance Roads and Surrounding Area in Ward No. 06 Byatarayanapura Sub Division

: Sri. K Lakshmi Narayana Reddy, No:688, 1st Floor, Vyalikaval Society, Near Chaitanya School, Veeranapalya, Bangalore-560045.

: BBMP/EE/BTP/WO/01/2021-22

: 09-05-2022

: Drain Side Wall - Fathima Furniture Opposite Road (Anam Enclave)

: 150X150X150 mm

: M20 / 7 Days Compressive Strength

: IS: 516 - 1959 (RA 2018) Methods of Tests for Strength of Concrete Cl.5

: 14/05/2022

| Identification Mark | Grade of concrete | Date of Casting | Date of Testing | Dimension of the Specimen (mm) | Cross sectional area (Sq.mm) | Weight of the sample (kg) | Failure Load (KN) | Compressive strength ($N/mm^2$) | Average Compressive Strength ($N/mm^2$) |
|---|---|---|---|---|---|---|---|---|---|
| Drain Side Wall - Fathima Furniture Opposite Road (Anam Enclave) | M20 | 07/05/2022 | 14/05/2022 | 151.88 X 150.49 X 149.78 | 22856 | 8.348 | 427.2 | 18.7 | 18.7 |
| Drain Side Wall - Fathima Furniture Opposite Road (Anam Enclave) | M20 | 07/05/2022 | 14/05/2022 | 150.93 X 149.36 X 151.86 | 22543 | 8.652 | 427.7 | 19.0 | |
| Drain Side Wall - Fathima Furniture Opposite Road (Anam Enclave) | M20 | 07/05/2022 | 14/05/2022 | 150.98 X 150.25 X 150.05 | 22685 | 8.800 | 420.5 | 18.5 | |

The results obtained are satisfactory as per standard requirements.

ಸಹಾಯಕ ಅಭಿಯಂತರರು
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ

Assistant Executive Engineer
Byatarayanapura Sub Division
B.B.M.P Bangalore-560024

CIVIL Pro Sig..... Date..... BANGALORE

FOR CIVIL Pro.
R.KARTHIK RECHAN
Authorized Signatory
Quality Manager

Page 1/1

****End of Report****

9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com



Scanned with CamScanner

CIVIL PRO
AN ISO 9001 : 2008 COMPANY & ACCREDITED LABORATORY AS PER ISO/IEC 17025:2017
# 4, 7TH MAIN MALLESWARAM, BANGALORE -3

Certificate No.: TC-5548

# TEST REPORT OF CEMENT CONCRETE CUBES

Format No: CP/TF/01

: CP-2022-07-01-01

: Improvements to Roads and Drains at Bharathnagara, Sadiq Layout, Anjanadru Layout Balance Roads and Surrounding Area in Ward No. 06 Byatarayanapura Sub Division — Date: 14/05/2022

: Sri. K Lakshmi Narayana Reddy, No:688, 1st Floor, Vyalikaval Society, Near Chaitanya School, Veeranapalya, Bangalore-560045.

: BBMP/EE/BTP/WO/01/2021-22

: 09-05-2022

: Drain Side Wall - Fathima Furniture Opposite Road (Anam Enclave)

: 150X150X150 mm

: M20 / 7 Days Compressive Strength

: IS: 516 - 1959 (RA 2018) Methods of Tests for Strength of Concrete Cl.5

: 14/05/2022

| Identification Mark | Grade of concrete | Date of Casting | Date of Testing | Dimension of the Specimen (mm) | Cross sectional area (Sq.mm) | Weight of the sample (kg) | Failure Load (KN) | Compressive strength ($N/mm^2$) | Average Compressive Strength ($N/mm^2$) |
|---|---|---|---|---|---|---|---|---|---|
| Drain Side Wall - Fathima Furniture Opposite Road (Anam Enclave) | M20 | 07/05/2022 | 14/05/2022 | 149.10 X 150.23 X 149.30 | 22399 | 8.938 | 417.5 | 18.6 | 18.4 |
| Drain Side Wall - Fathima Furniture Opposite Road (Anam Enclave) | M20 | 07/05/2022 | 14/05/2022 | 151.50 X 150.73 X 150.97 | 22835 | 8.559 | 420.5 | 18.4 | |
| Drain Side Wall - Fathima Furniture Opposite Road (Anam Enclave) | M20 | 07/05/2022 | 14/05/2022 | 150.63 X 149.60 X 151.59 | 22536 | 8.235 | 407.6 | 18.1 | |

Results obtained are satisfactory as per standard requirements.

ಸಹಾಯಕ ಅಭಿಯಂತರರು
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ

CIVIL Pro Sig..... Date..... BANGALORE

FOR CIVIL Pro.
R KARTHIK RECHAN
Authorized Signatory
Quality Manager

Assistant Executive Engineer
Byatarayanapura Sub Division
B.B.M.P Bangalore-560024


****End of Report****

9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com


Scanned with CamScanner

CIVIL PRO
AN ISO 9001 : 2008 COMPANY & ACCREDITED LABORATORY AS PER ISO/IEC 17025:2017
# 4, 7TH MAIN MALLESWARAM, BANGALORE -3

Certificate No.: TC-5548

# TEST REPORT OF CEMENT CONCRETE CUBES

Format No: CP/TF/01

: CP-2022-07-01-01

: Improvements to Roads and Drains at Bharathnagara, Sadiq Layout, Anjanadru Layout Balance Roads and Surrounding Area in Ward No. 06 Byatarayanapura Sub Division

Date: 10/06/2022

: Sri. K Lakshmi Narayana Reddy, No:688, 1st Floor, Vyalikaval Society, Near Chaitanya School, Veeranapalya, Bangalore-560045.

: BBMP/EE/BTP/WO/01/2021-22

: 16-05-2022

: Drain Side Wall - Fathima Furniture Beside Road (Anam Enclave)

: 150X150X150 mm

: M20 / 28 Days Compressive Strength

: IS: 516 - 1959 (RA 2018) Methods of Tests for Strength of Concrete Cl.5

: 10/06/2022

| Identification Mark | Grade of concrete | Date of Casting | Date of Testing | Dimension of the Specimen (mm) | Cross sectional area (Sq.mm) | Weight of the sample (kg) | Failure Load (KN) | Compressive strength ($N/mm^2$) | Average Compressive Strength ($N/mm^2$) |
|---|---|---|---|---|---|---|---|---|---|
| Side Wall - ma Furniture Road (Anam Enclave) | M20 | 13/05/2022 | 10/06/2022 | 150.01 X 151.28 X 149.93 | 22694 | 8.774 | 529.1 | 23.3 | 23.0 |
| Side Wall - ma Furniture Road (Anam Enclave) | M20 | 13/05/2022 | 10/06/2022 | 151.83 X 150.69 X 149.58 | 22880 | 8.728 | 517.2 | 22.6 | |
| Side Wall - ma Furniture Road (Anam Enclave) | M20 | 13/05/2022 | 10/06/2022 | 150.47 X 150.07 X 150.51 | 22581 | 8.498 | 523.9 | 23.2 | |

obtained are satisfactory as per standard requirements.

Assistant Executive Engineer
Byatarayanapura Sub Division
BBMP Bangalore-560092

CIVIL Pro Sig..... Date..... BANGALORE

FOR CIVIL Pro.
R KARTHIK RECHAN
Authorized Signatory
Quality Manager



****End of Report****

72924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

LABORATORY | STRUCTURAL | ENVIRONMENTAL
SURVEYING SERVICES

Scanned with CamScanner

CIVIL PRO
AN ISO 9001 : 2008 COMPANY & ACCREDITED LABORATORY AS PER ISO/IEC 17025:2017
# 4, 7TH MAIN MALLESWARAM, BANGALORE -3

Certificate No.: TC-5548

# TEST REPORT OF CEMENT CONCRETE CUBES

Format No: CP/TF/01

: CP-2022-07-01-01

: Improvements to Roads and Drains at Bharathnagara, Sadiq Layout, Anjanadru Layout Balance Roads and Surrounding Area in Ward No. 06 Byatarayanapura Sub Division

Date: 20/05/2022

: Sri. K Lakshmi Narayana Reddy, No:688, 1st Floor, Vyalikaval Society, Near Chaitanya School, Veeranapalya, Bangalore-560045.

: BBMP/EE/BTP/WO/01/2021-22

: 16-05-2022

: Drain Side Wall - Fathima Furniture Beside Road (Anam Enclave)

: 150X150X150 mm

: M20 / 7 Days Compressive Strength

: IS: 516 - 1959 (RA 2018) Methods of Tests for Strength of Concrete Cl.5

: 20/05/2022

| Identification Mark | Grade of concrete | Date of Casting | Date of Testing | Dimension of the Specimen (mm) | Cross sectional area (Sq.mm) | Weight of the sample (kg) | Failure Load (KN) | Compressive strength ($N/mm^2$) | Average Compressive Strength ($N/mm^2$) |
|---|---|---|---|---|---|---|---|---|---|
| Drain Side Wall - Fathima Furniture Beside Road (Anam Enclave) | M20 | 13/05/2022 | 20/05/2022 | 150.62 X 149.73 X 151.75 | 22552 | 8.349 | 420.7 | 18.7 | 18.5 |
| Drain Side Wall - Fathima Furniture Beside Road (Anam Enclave) | M20 | 13/05/2022 | 20/05/2022 | 151.97 X 150.75 X 150.73 | 22910 | 8.239 | 419.6 | 18.3 | |
| Drain Side Wall - Fathima Furniture Beside Road (Anam Enclave) | M20 | 13/05/2022 | 20/05/2022 | 149.43 X 150.39 X 151.56 | 22472 | 8.291 | 418.3 | 18.6 | |

The results obtained are satisfactory as per standard requirements.

ಸಹಾಯಕ ಅಭಿಯಂತರರು
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ

Assistant Executive Engineer
Byatarayanapura Sub Division
B.B.M.P Bangalore-560024

CIVIL Pro Sig..... Date..... BANGALORE

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

Page 1/1
****End of Report****



Scanned with CamScanner

CIVIL PRO
AN ISO 9001 : 2008 COMPANY & ACCREDITED LABORATORY AS PER ISO/IEC 17025:2017
# 4, 7TH MAIN MALLESWARAM, BANGALORE -3

Certificate No.: TC-5548

# TEST REPORT OF CEMENT CONCRETE CUBES

Format No: CP/TF/01

: CP-2022-07-01-01

: Improvements to Roads and Drains at Bharathnagara, Sadiq Layout, Anjanadru Layout Balance Roads and Surrounding Area in Ward No. 06 Byatarayanapura Sub Division

Date: 26/05/2022

: Sri. K Lakshmi Narayana Reddy, No:688, 1st Floor, Vyalikaval Society, Near Chaitanya School, Veeranapalya, Bangalore-560045.

: BBMP/EE/BTP/WO/01/2021-22

: 21-05-2022

: Drain Side Wall - 4th Cross Road (Chikkanna Layout)

: 150X150X150 mm

: M20 / 7 Days Compressive Strength

: IS: 516 - 1959 (RA 2018) Methods of Tests for Strength of Concrete Cl.5

: 26/05/2022

| Identification Mark | Grade of concrete | Date of Casting | Date of Testing | Dimension of the Specimen (mm) | Cross sectional area (Sq.mm) | Weight of the sample (kg) | Failure Load (KN) | Compressive strength ($N/mm^2$) | Average Compressive Strength ($N/mm^2$) |
|---|---|---|---|---|---|---|---|---|---|
| Side Wall - 4th Cross Road kkanna Layout) | M20 | 19/05/2022 | 26/05/2022 | 149.83 X 150.83 X 151.55 | 22598 | 9.056 | 422.5 | 18.7 | 18.8 |
| Side Wall - 4th Cross Road kkanna Layout) | M20 | 19/05/2022 | 26/05/2022 | 149.19 X 151.30 X 151.70 | 22572 | 8.149 | 424.5 | 18.8 | |
| Side Wall - 4th Cross Road kkanna Layout) | M20 | 19/05/2022 | 26/05/2022 | 149.92 X 150.80 X 150.46 | 22607 | 8.369 | 427.2 | 18.9 | |

ults obtained are satisfactory as per standard requirements.

ಸಹಾಯಕ ಅಭಿಯಂತರರು
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬಾ...

CIVIL Pro Sig..... Date..... BANGALORE

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

Assistant Exec... Engineer
Byatarayanapura Sub Division
B.B.M.P Bangalore-560024

Page 1/1

****End of Report****



Scanned with CamScanner

Certificate No.: TC-5548

# TEST REPORT OF CEMENT CONCRETE CUBES

Format No: CP/TF/01

Date: 16/06/2022

| | | |
|---|---|---|
| Job ID | : | CP-2022-07-01-01 |
| Project Name | : | Improvements to Roads and Drains at Bharathnagara, Sadiq Layout, Anjanadru Layout Balance Roads and Surrounding Area in Ward No. 06 Byatarayanapura Sub Division |
| Agency | : | Sri. K Lakshmi Narayana Reddy, No:688, 1st Floor, Vyalikaval Society, Near Chaitanya School, Veeranapalya, Bangalore-560045. |
| Customer's Reference | : | BBMP/EE/BTP/WO/01/2021-22 |
| Date of Receipt | : | 21-05-2022 |
| Customer ID | : | Drain Side Wall - 4th Cross Road (Chikkanna Layout) |
| Sample Type /Size | : | 150X150X150 mm |
| Sample grade/Age | : | M20 / 28 Days Compressive Strength |
| Reference to BIS codes | : | IS: 516 - 1959 (RA 2018) Methods of Tests for Strength of Concrete Cl.5 |
| Date of test | : | 16/06/2022 |

| Sl. No. | Identification Mark | Grade of concrete | Date of Casting | Date of Testing | Dimension of the Specimen (mm) | Cross sectional area (Sq.mm) | Weight of the sample (kg) | Failure Load (KN) | Compressive strength ($N/mm^2$) | Average Compressive Strength ($N/mm^2$) |
|---|---|---|---|---|---|---|---|---|---|---|
| | Drain Side Wall - 4th Cross Road (Chikkanna Layout) | M20 | 19/05/2022 | 16/06/2022 | 149.20 X 150.40 X 149.02 | 22440 | 8.247 | 516.5 | 23.0 | 22.8 |
| | Drain Side Wall - 4th Cross Road (Chikkanna Layout) | M20 | 19/05/2022 | 16/06/2022 | 149.06 X 150.61 X 150.99 | 22450 | 8.119 | 497.5 | 22.2 | |
| | Drain Side Wall - 4th Cross Road (Chikkanna Layout) | M20 | 19/05/2022 | 16/06/2022 | 149.47 X 150.46 X 150.39 | 22489 | 8.276 | 525.2 | 23.4 | |

The results obtained are satisfactory as per standard requirements.

ಸಹಾಯಕ ಅಭಿಯಂತರರು
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ

CIVIL Pro Sig..... Date..... BANGALORE

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

Assistant Executive Engineer
Byatarayanapura Sub Division
BBMP Bangalore-560024

Page 1/1
****End of Report****



Scanned with CamScanner

CIVIL PRO
AN ISO 9001 : 2008 COMPANY & ACCREDITED LABORATORY AS PER ISO/IEC 17025:2017
# 4, 7TH MAIN MALLESWARAM, BANGALORE -3
Certificate No.: TC-5548

Format No: CP/TF/01

# TEST REPORT OF CEMENT CONCRETE CUBES

Lab ID : CP-2022-07-01-01

Date: 26/05/2022

Project Name : Improvements to Roads and Drains at Bharathnagara, Sadiq Layout, Anjanadru Layout Balance Roads and Surrounding Area in Ward No. 06 Byatarayanapura Sub Division

Agency : Sri. K Lakshmi Narayana Reddy, No:688, 1st Floor, Vyalikaval Society, Near Chaitanya School, Veeranapalya, Bangalore-560045.

Customer's Reference : BBMP/EE/BTP/WO/01/2021-22

Date of Receipt : 21-05-2022

Customer ID : Drain Side Wall - 4th Cross Road (Chikkanna Layout)

Sample Type /Size : 150X150X150 mm

Sample grade/Age : M20 / 7 Days Compressive Strength

Reference to BIS codes : IS: 516 - 1959 (RA 2018) Methods of Tests for Strength of Concrete Cl.5

Date of test : 26/05/2022

| Sl. No. | Identification Mark | Grade of concrete | Date of Casting | Date of Testing | Dimension of the Specimen (mm) | Cross sectional area (Sq.mm) | Weight of the sample (kg) | Failure Load (KN) | Compressive strength ($N/mm^2$) | Average Compressive Strength ($N/mm^2$) |
|---|---|---|---|---|---|---|---|---|---|---|
| 1 | Drain Side Wall - 4th Cross Road (Chikkanna Layout) | M20 | 19/05/2022 | 26/05/2022 | 149.96 X 151.01 X 150.67 | 22644 | 8.857 | 428.8 | 18.9 | 18.6 |
| 2 | Drain Side Wall - 4th Cross Road (Chikkanna Layout) | M20 | 19/05/2022 | 26/05/2022 | 150.76 X 151.13 X 151.02 | 22784 | 8.100 | 419.0 | 18.4 | |
| 3 | Drain Side Wall - 4th Cross Road (Chikkanna Layout) | M20 | 19/05/2022 | 26/05/2022 | 149.69 X 149.24 X 151.76 | 22340 | 8.924 | 412.8 | 18.5 | |

The results obtained are satisfactory as per standard requirements.

ಸಹಾಯಕ ಅಭಿಯಂತರರು
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ

CIVIL Pro Sig..... Date..... BANGALORE

FOR CIVIL Pro.

KARTHIK RECHAN
Authorized Signatory
Quality Manager

Assistant Executive Engineer
Byatarayanapura Sub Division
B.B.M.P Bangalore-560024

Page 1/1

****End of Report****



Scanned with CamScanner

CIVIL PRO
AN ISO 9001 : 2008 COMPANY & ACCREDITED LABORATORY AS PER ISO/IEC 17025:2017
# 4, 7TH MAIN MALLESWARAM, BANGALORE -3

Certificate No.: TC-5548

# TEST REPORT OF CEMENT CONCRETE CUBES

Format No: CP/TF/01

Date: 16/06/2022

| | | |
|---|---|---|
| Lab ID | : | CP-2022-07-01-01 |
| Project Name | : | Improvements to Roads and Drains at Bharathnagara, Sadiq Layout, Anjanadru Layout Balance Roads and Surrounding Area in Ward No. 06 Byatarayanapura Sub Division |
| Agency | : | Sri. K Lakshmi Narayana Reddy, No:688, 1st Floor, Vyalikaval Society, Near Chaitanya School, Veeranapalya, Bangalore-560045. |
| Customer's Reference | : | BBMP/EE/BTP/WO/01/2021-22 |
| Date of Receipt | : | 21-05-2022 |
| Customer ID | : | Drain Side Wall - 4th Cross Road (Chikkanna Layout) |
| Sample Type /Size | : | 150X150X150 mm |
| Sample grade/Age | : | M20 / 28 Days Compressive Strength |
| Reference to BIS codes | : | IS: 516 - 1959 (RA 2018) Methods of Tests for Strength of Concrete Cl.5 |
| Date of test | : | 16/06/2022 |

| Sl. No. | Identification Mark | Grade of concrete | Date of Casting | Date of Testing | Dimension of the Specimen (mm) | Cross sectional area (Sq.mm) | Weight of the sample (kg) | Failure Load (KN) | Compressive strength ($N/mm^2$) | Average Compressive Strength ($N/mm^2$) |
|---|---|---|---|---|---|---|---|---|---|---|
| 1 | Drain Side Wall - 4th Cross Road (Chikkanna Layout) | M20 | 19/05/2022 | 16/06/2022 | 151.92 X 149.54 X 151.91 | 22717 | 8.384 | 539.0 | 23.7 | 23.0 |
| 2 | Drain Side Wall - 4th Cross Road (Chikkanna Layout) | M20 | 19/05/2022 | 16/06/2022 | 149.09 X 149.44 X 149.18 | 22281 | 8.905 | 494.4 | 22.2 | |
| 3 | Drain Side Wall - 4th Cross Road (Chikkanna Layout) | M20 | 19/05/2022 | 16/06/2022 | 149.64 X 151.76 X 151.98 | 22710 | 8.779 | 523.3 | 23.0 | |

The results obtained are satisfactory as per standard requirements.

ಸಹಾಯಕ ಅಭಿಯಂತರು
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ

CIVIL Pro Sig..... Date..... BANGALORE

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

Assistant Executive Engineer
Byatarayanapura Sub Division
B.B.M.P Bangalore-560024

Page 1/1
****End of Report****



Scanned with CamScanner

Format No: CP/TF/01

# TEST REPORT OF CEMENT CONCRETE CUBES

| | | |
|---|---|---|
| Lab ID | : | CP-2022-07-01-01 |
| Project Name | : | Improvements to Roads and Drains at Bharathnagara, Sadiq Layout, Anjanadru Layout Balance Roads and Surrounding Area in Ward No. 06 Byatarayanapura Sub Division |
| Agency | : | Sri. K Lakshmi Narayana Reddy, No:688, 1st Floor, Vyalikaval Society, Near Chaitanya School, Veeranapalya, Bangalore-560045. |
| Customer's Reference | : | BBMP/EE/BTP/WO/01/2021-22 |
| Date of Receipt | : | 21-05-2022 |
| Customer ID | : | Drain Side Wall - 4th Cross Road (Chikkanna Layout) |
| Sample Type /Size | : | 150X150X150 mm |
| Sample grade/Age | : | M20 / 7 Days Compressive Strength |
| Reference to BIS codes | : | IS: 516 - 1959 (RA 2018) Methods of Tests for Strength of Concrete Cl.5 |
| Date of test | : | 26/05/2022 |

Date: 26/05/2022

| Sl. No. | Identification Mark | Grade of concrete | Date of Casting | Date of Testing | Dimension of the Specimen (mm) | Cross sectional area (Sq.mm) | Weight of the sample (kg) | Failure Load (KN) | Compressive strength ($N/mm^2$) | Average Compressive Strength ($N/mm^2$) |
|---|---|---|---|---|---|---|---|---|---|---|
| 1 | Drain Side Wall - 4th Cross Road (Chikkanna Layout) | M20 | 19/05/2022 | 26/05/2022 | 150.58 X 149.35 X 151.46 | 22489 | 9.077 | 422.3 | 18.8 | 18.8 |
| 2 | Drain Side Wall - 4th Cross Road (Chikkanna Layout) | M20 | 19/05/2022 | 26/05/2022 | 151.53 X 150.99 X 151.38 | 22880 | 8.220 | 427.4 | 18.7 | |
| 3 | Drain Side Wall - 4th Cross Road (Chikkanna Layout) | M20 | 19/05/2022 | 26/05/2022 | 151.83 X 149.28 X 149.61 | 22666 | 9.045 | 428.1 | 18.9 | |

The results obtained are satisfactory as per standard requirements.

ಸಹಾಯಕ ಅಭಿಯಂತರರು
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ

CIVIL Pro Sig..... Date..... BANGALORE

FOR CIVIL Pro.
R KARTHIK RECHAN
Authorized Signatory
Quality Manager

Assistant Executive Engineer
Byatarayanapura Sub Division
B.B.M.P, Bangalore-560024

Page 1/1
****End of Report****



Scanned with CamScanner

CIVIL PRO
AN ISO 9001 : 2008 COMPANY & ACCREDITED LABORATORY AS PER ISO/IEC 17025:2017
# 4, 7TH MAIN MALLESWARAM, BANGALORE -3

Certificate No.: TC-5548

# TEST REPORT OF CEMENT CONCRETE CUBES

Format No: CP/TF/01

| | | |
|---|---|---|
| Lab ID | : | CP-2022-07-01-01 |
| Project Name | : | Improvements to Roads and Drains at Bharathnagara, Sadiq Layout, Anjanadru Layout Balance Roads and Surrounding Area in Ward No. 06 Byatarayanapura Sub Division |
| Agency | : | Sri. K Lakshmi Narayana Reddy, No:688, 1st Floor, Vyalikaval Society, Near Chaitanya School, Veeranapalya, Bangalore-560045. |
| Customer's Reference | : | BBMP/EE/BTP/WO/01/2021-22 |
| Date of Receipt | : | 21-05-2022 |
| Customer ID | : | Drain Side Wall - 4th Cross Road (Chikkanna Layout) |
| Sample Type /Size | : | 150X150X150 mm |
| Sample grade/Age | : | M20 / 28 Days Compressive Strength |
| Reference to BIS codes | : | IS: 516 - 1959 (RA 2018) Methods of Tests for Strength of Concrete Cl.5 |
| Date of test | : | 16/06/2022 |

Date: 16/06/2022

| Sl. No. | Identification Mark | Grade of concrete | Date of Casting | Date of Testing | Dimension of the Specimen (mm) | Cross sectional area (Sq.mm) | Weight of the sample (kg) | Failure Load (KN) | Compressive strength ($N/mm^2$) | Average Compressive Strength ($N/mm^2$) |
|---|---|---|---|---|---|---|---|---|---|---|
| 1 | Drain Side Wall - 4th Cross Road (Chikkanna Layout) | M20 | 19/05/2022 | 16/06/2022 | 151.92 X 151.27 X 150.36 | 22980 | 9.074 | 540.3 | 23.5 | 23.0 |
| 2 | Drain Side Wall - 4th Cross Road (Chikkanna Layout) | M20 | 19/05/2022 | 16/06/2022 | 151.92 X 150.51 X 151.50 | 22865 | 8.524 | 506.7 | 22.2 | |
| 3 | Drain Side Wall - 4th Cross Road (Chikkanna Layout) | M20 | 19/05/2022 | 16/06/2022 | 149.11 X 151.44 X 151.98 | 22581 | 9.049 | 529.6 | 23.5 | |

The results obtained are satisfactory as per standard requirements.

ಸಹಾಯಕ ಅಭಿಯಂತರರು
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ

CIVIL Pro Sig..... Date..... BANGALORE

FOR CIVIL Pro.
R KARTHIK RECHAN
Authorized Signatory
Quality Manager

Page 1/1
****End of Report****

Assistant Executive Engineer
Byatarayanapura Sub Division
B.B.M.P. Bangalore-560024

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com



Scanned with CamScanner

CIVIL PRO
AN ISO 9001 : 2008 COMPANY & ACCREDITED LABORATORY AS PER ISO/IEC 17025:2017
# 4, 7TH MAIN MALLESWARAM, BANGALORE -3

Certificate No.: TC-5548

# TEST REPORT OF CEMENT CONCRETE CUBES

Format No: CP/TF/01

Lab ID : CP-2022-07-01-01

Date: 26/05/2022

Project Name : Improvements to Roads and Drains at Bharathnagara, Sadiq Layout, Anjanadru Layout Balance Roads and Surrounding Area in Ward No. 06 Byatarayanapura Sub Division

Agency : Sri. K Lakshmi Narayana Reddy, No:688, 1st Floor, Vyalikaval Society, Near Chaitanya School, Veeranapalya, Bangalore-560045.

Customer's Reference : BBMP/EE/BTP/WO/01/2021-22

Date of Receipt : 21-05-2022

Customer ID : Drain Side Wall - 4th Cross Road (Chikkanna Layout)

Sample Type /Size : 150X150X150 mm

Sample grade/Age : M20 / 7 Days Compressive Strength

Reference to BIS codes : IS: 516 - 1959 (RA 2018) Methods of Tests for Strength of Concrete Cl.5

Date of test : 26/05/2022

| Sl. No. | Identification Mark | Grade of concrete | Date of Casting | Date of Testing | Dimension of the Specimen (mm) | Cross sectional area (Sq.mm) | Weight of the sample (kg) | Failure Load (KN) | Compressive strength ($N/mm^2$) | Average Compressive Strength ($N/mm^2$) |
|---|---|---|---|---|---|---|---|---|---|---|
| 1 | Drain Side Wall - 4th Cross Road (Chikkanna Layout) | M20 | 19/05/2022 | 26/05/2022 | 151.90 X 150.67 X 149.23 | 22887 | 8.422 | 433.8 | 19.0 | 18.7 |
| 2 | Drain Side Wall - 4th Cross Road (Chikkanna Layout) | M20 | 19/05/2022 | 26/05/2022 | 150.43 X 150.74 X 151.84 | 22676 | 8.216 | 424.7 | 18.7 | |
| 3 | Drain Side Wall - 4th Cross Road (Chikkanna Layout) | M20 | 19/05/2022 | 26/05/2022 | 149.52 X 151.59 X 151.02 | 22666 | 8.520 | 416.8 | 18.4 | |

The results obtained are satisfactory as per standard requirements.

ಸಹಾಯಕ ಅಭಿಯಂತರರು
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ

CIVIL Pro Sig..... Date..... BANGALORE

FOR CIVIL Pro.
R.KARTHIK RECHAN
Authorized Signatory
Quality Manager



****End of Report****

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL | ENVIRONMENTAL
WATER TESTING | GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES

Scanned with CamScanner

CIVIL PRO

AN ISO 9001 : 2008 COMPANY & ACCREDITED LABORATORY AS PER ISO/IEC 17025:2017

# 4, 7TH MAIN MALLESWARAM, BANGALORE -3

Certificate No.: TC-5548

Format No: CP/TF/01

# TEST REPORT OF CEMENT CONCRETE CUBES

| | | |
|---|---|---|
| | : CP-2022-07-01-01 | Date: 16/06/2022 |
| Name | : Improvements to Roads and Drains at Bharathnagara, Sadiq Layout, Anjanadru Layout Balance Roads and Surrounding Area in Ward No. 06 Byatarayanapura Sub Division | |
| | : Sri. K Lakshmi Narayana Reddy, No:688, 1st Floor, Vyalikaval Society, Near Chaitanya School, Veeranapalya, Bangalore-560045. | |
| Customer's Reference | : BBMP/EE/BTP/WO/01/2021-22 | |
| Date of Receipt | : 21-05-2022 | |
| Customer ID | : Drain Side Wall - 4th Cross Road (Chikkanna Layout) | |
| Sample Type /Size | : 150X150X150 mm | |
| Sample grade/Age | : M20 / 28 Days Compressive Strength | |
| Reference to BIS codes | : IS: 516 - 1959 (RA 2018) Methods of Tests for Strength of Concrete Cl.5 | |
| Date of test | : 16/06/2022 | |

| Identification Mark | Grade of concrete | Date of Casting | Date of Testing | Dimension of the Specimen (mm) | Cross sectional area (Sq.mm) | Weight of the sample (kg) | Failure Load (KN) | Compressive strength ($N/mm^2$) | Average Compressive Strength ($N/mm^2$) |
|---|---|---|---|---|---|---|---|---|---|
| Drain Side Wall - 4th Cross Road (Chikkanna Layout) | M20 | 19/05/2022 | 16/06/2022 | 151.98 X 149.37 X 151.98 | 22701 | 8.346 | 539.0 | 23.7 | 23.4 |
| Drain Side Wall - 4th Cross Road (Chikkanna Layout) | M20 | 19/05/2022 | 16/06/2022 | 149.42 X 150.30 X 151.27 | 22458 | 8.125 | 509.7 | 22.7 | |
| Drain Side Wall - 4th Cross Road (Chikkanna Layout) | M20 | 19/05/2022 | 16/06/2022 | 149.07 X 150.22 X 151.92 | 22393 | 8.891 | 530.6 | 23.7 | |

The results obtained are satisfactory as per standard requirements.

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ

Assistant Executive Engineer
Byatarayanapura Sub Division
B.B.M.P Bangalore-560024

CIVIL Pro Sig..... Date..... BANGALORE

FOR CIVIL Pro.

R K ARTHIK RECHAN
Authorized Signatory
Quality Manager

Page 1 / 1

****End of Report****

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL | ENVIRONMENTAL
WATER TESTING | GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES

Scanned with CamScanner

CIVIL PRO
AN ISO 9001 : 2008 COMPANY & ACCREDITED LABORATORY AS PER ISO/IEC 17025:2017
# 4, 7TH MAIN MALLESWARAM, BANGALORE -3
Certificate No.: TC-5548

Format No: CP/TF/01

# TEST REPORT ON PHYSICAL REQUIREMENTS OF SOLID CONCRETE BLOCKS

| | | |
|---|---|---|
| Lab ID | : | CP-2022-07-01-01 Date: 22-04-2022 |
| Project Name | : | Improvements to Roads and Drains at Bharathnagara, Sadiq Layout, Anjanadru Layout Balance Roads and Surrounding Area in Ward No. 06 Byatarayanapura Sub Division |
| Agency | : | Sri. K Lakshmi Narayana Reddy, No:688, 1st Floor, Vyalikaval Society, Near Chaitanya School, Veeranapalya, Bangalore-560045. |
| Customer's Reference | : | BBMP/EE/BTP/WO/01/2021-22 |
| Date of Receipt | : | 18-04-2022 |
| Sample Type/Size | : | Solid concrete blocks size (400X150X200)mm |
| Reference to BIS codes | : | IS : 2185 (Part 1) : 2005(RA 2020) Concrete Masonry Specification Part 1:Hollow and Solid Concrete Blocks (Dimensions -Annex-B, Clause 9.2 and 10 , Block density Annex -C Clause 9.3 and10, Compressive strength Annex -D Clause 9.4 and 10, Water absorption Annex -E Clause 9.5 and 10) |
| Date of test | : | 18-04-2022 |

BLOCK DENSITY:

| Sl. No. | Measurement of overall Dimensions of Individual Blocks | | | Overall Volume of the Block in Cubic Centimetres | Weight of Oven Dried Block in Kilograms to the nearest 10 Gram | Block Density in Kg/cum*$10^6$ | Avg.Block Density in (Kg/cum) | As per IS 2185(Part 1) :2005 (RA 2010) |
|---|---|---|---|---|---|---|---|---|
| | Length | Breadth | Height | | | | | |
| | mm | mm | mm | ($Cm^3$) | Kg | $Kg/m^3$ | $Kg/m^3$ | |
| 1 | 402 | 151 | 203 | 12323 | 22.205 | 1802.0 | 1806.3 | Not less than 1800$Kg/m^3$ |
| 2 | 404 | 148 | 198 | 11839 | 22.328 | 1886.0 | | |
| 3 | 402 | 152 | 200 | 12221 | 21.154 | 1731.0 | | |

WATER ABSORPTION:

| Sl. No. | Wet weight after water absorption | Dry weight (Oven dry) | Water Absorption | Avg.Water Absorption | As per IS 2185(Part 1):2005 (RA 2010) |
|---|---|---|---|---|---|
| | kg | kg | % | % | |
| 1 | 33.91 | 32.25 | 4.89 | 4.25 | Shall not be more than 10% by mass |
| 2 | 33.57 | 32.14 | 4.28 | | |
| 3 | 33.44 | 32.24 | 3.59 | | |



CIVIL Pro Sig..... Date..... BANGALORE

Assistant Executive Engineer
Byatarayanapura Sub Division
B.B.M.P Bangalore-560024

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL | ENVIRONMENTAL
WATER TESTING | GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES

Scanned with CamScanner

Lab ID : CP-2022-07-01-01

Date: 22-04-2022

DIMENSION ANALYSIS

| Sl.no | Length mm | Breadth mm | Height mm | Requirement as per IS 2185(Part 1):2005 |
|---|---|---|---|---|
| 1 | 401 | 153 | 201 | Length : ± 5mm<br>Breadth : ± 3mm<br>Height : ± 3mm |
| 2 | 403 | 153 | 202 | |
| 3 | 403 | 151 | 199 | |
| 4 | 403 | 153 | 202 | |
| 5 | 402 | 153 | 201 | |
| 6 | 400 | 151 | 201 | |
| 7 | 400 | 152 | 200 | |
| 8 | 401 | 152 | 199 | |
| 9 | 401 | 153 | 203 | |
| 10 | 401 | 153 | 200 | |
| 11 | 400 | 150 | 202 | |
| 12 | 401 | 153 | 201 | |
| 13 | 401 | 152 | 200 | |
| 14 | 400 | 152 | 199 | |
| 15 | 403 | 149 | 199 | |
| 16 | 402 | 150 | 200 | |
| 17 | 400 | 149 | 202 | |
| 18 | 400 | 151 | 203 | |
| 19 | 399 | 152 | 200 | |
| 20 | 400 | 152 | 201 | |
| Average of 20 | **401** | **152** | **201** | |



ಸಹಾಯಕ ಅಭಿಯಂತರರು

CIVIL Pro Sig..... Date..... BANGALORE

Assistant Executive Engineer
Byatarayanapura Sub Division
B.B.M.P, Bangalore-560024

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com



Scanned with CamScanner

Lab ID : CP-2022-07-01-01

Date: 22-04-2022

COMPRESSIVE STRENGTH:

| Sl. No. | Size of solid block | | Area | Failure Load | Compressive strength | Average Compressive strength |
|---|---|---|---|---|---|---|
| | Length | Breadth | | | | |
| | mm | mm | ($mm^2$) | (KN) | $N/mm^2$ | ($N/mm^2$) |
| 1 | 400 | 153 | 61055 | 286.8 | 4.7 | 4.7 |
| 2 | 403 | 153 | 61549 | 284.6 | 4.6 | |
| 3 | 403 | 151 | 60656 | 290.8 | 4.8 | |
| 4 | 403 | 153 | 61522 | 290.7 | 4.7 | |
| 5 | 402 | 153 | 61390 | 282.8 | 4.6 | |
| 6 | 400 | 151 | 60485 | 288.9 | 4.8 | |
| 7 | 400 | 152 | 60712 | 285.4 | 4.7 | |
| 8 | 401 | 152 | 61205 | 289.1 | 4.7 | |

As per IS Requirements (Table 2, Clause 5.1, 5.2 and 9.4)

| Compressive strength | | |
|---|---|---|
| Grade | Minimum average | Minimum Individual units. |
| C (5.0) | 5.00 $N/mm^2$ | 4.00 $N/mm^2$ |
| C (4.0) | 4.00 $N/mm^2$ | 3.20 $N/mm^2$ |

* The Results Obtained are Satisfactory as per Standard Requirements

ಸಹಾಯಕ ಅಭಿಯಂತರರು
ಎಬಿಎಂಪಿ ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ

FOR CIVIL Pro.
R KARTHIK RECHAN
Authorized Signatory
Quality Manager

Assistant Executive Engineer
Byatarayanapura Sub Division
BBMP Bangalore-560024


****End of Report****

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL | ENVIRONMENTAL
WATER TESTING | GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES

Scanned with CamScanner

CIVIL PRO
AN ISO 9001 : 2008 COMPANY & ACCREDITED LABORATORY AS PER ISO/IEC 17025:2017
# 4, 7TH MAIN MALLESWARAM, BANGALORE -3

Certificate No.: TC-5548

# TEST RESULTS OF GRADATION FOR GSB
## (IS 2386:(Part 1) 1963 (RA2011)

Lab ID : CP-RW-2022-07-01-01 Date: 26-05-2022

Project Name : Improvements to Roads and Drains at Bharathnagara, Sadiq Layout, Anjanadru Layout Balance Roads and Surrounding Area in Ward No. 06 Byatarayanapura Sub Division

Agency : Sri. K Lakshmi Narayana Reddy, No:688, 1st Floor, Vyalikaval Society, Near Chaitanya School, Veeranapalya, Bangalore-560045.

Customer Reference : BBMP/EE/BTP/WO/01/2021-22

Date of Receipt : 24-05-2022

Type of Mix : GSB (Granular Sub Base)

Date of test : 24-05-2022

Oven Dry Weight : 10000 Grams

| IS Sieve Size(mm) | Weight Retained (gm) | Cumulative Weight Retained (gm) | % Cumulative Weight Retained | % Passing | Spec. Limit Vide Table 400.1 MORTH Specification |
|---|---|---|---|---|---|
| 75 | 0 | 0 | 0.0 | 100.0 | 100 |
| 53 | 997 | 997 | 10.0 | 90.0 | 80-100 |
| 26.5 | 1685 | 2682 | 26.8 | 73.2 | 55-90 |
| 9.5 | 1292 | 3974 | 39.7 | 60.3 | 35-65 |
| 4.75 | 1490 | 5464 | 54.6 | 45.4 | 25-55 |
| 2.36 | 2456 | 7920 | 79.2 | 20.8 | 20-40 |
| 0.425 | 1020 | 8940 | 89.4 | 10.6 | 10-25 |
| 0.075 | 659 | 9599 | 96.0 | 4.0 | 0-5 |

**TESTS ON FILLER SCREEN MATERIALS**

| Sl no | Particulars | Test results | Spec.Limit Vide Table |
|---|---|---|---|
| 1 | Liquid Limit, % | 21.33% | Maximum 25 |
| 2 | Plasticity index, % | Non plastic | Maximum 6 |

* The results obtained are satisfactory as per standard requirements.

ಸಹಾಯಕ ಅಭಿಯಂತರರು

FOR CIVIL Pro.

Sig.....R'KARTHIK RECHAN
Date.....Authorized Signatory
Quality Manager

Page 1/1
*End of Report*

Assistant Executive Engineer
Byatarayanapura Sub Division
B.B.M.P. Bangalore-560 ...4

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com



Scanned with CamScanner

CIVIL PRO
AN ISO 9001 : 2008 COMPANY & ACCREDITED LABORATORY AS PER ISO/IEC 17025:2017
# 4, 7TH MAIN MALLESWARAM, BANGALORE -3

Certificate No.: TC-5548

# TEST RESULTS OF GRADATION FOR GSB
## (IS 2386:(Part 1) 1963 (RA2011)

Lab ID : CP-RW-2022-07-01-01

Date: 26-05-2022

Project Name : Improvements to Roads and Drains at Bharathnagara, Sadiq Layout, Anjanadru Layout Balance Roads and Surrounding Area in Ward No. 06 Byatarayanapura Sub Division

Agency : Sri. K Lakshmi Narayana Reddy, No:688, 1st Floor, Vyalikaval Society, Near Chaitanya School, Veeranapalya, Bangalore-560045.

Customer Reference : BBMP/EE/BTP/WO/01/2021-22

Date of Receipt : 24-05-2022

Type of Mix : GSB (Granular Sub Base)

Date of test : 24-05-2022

Oven Dry Weight : 10000 Grams

| IS Sieve Size(mm) | Weight Retained (gm) | Cumulative Weight Retained (gm) | % Cumulative Weight Retained | % Passing | Spec. Limit Vide Table 400.1 MORTH Specification |
|---|---|---|---|---|---|
| 75 | 0 | 0 | 0.0 | 100.0 | 100 |
| 53 | 997 | 997 | 10.0 | 90.0 | 80-100 |
| 26.5 | 1685 | 2682 | 26.8 | 73.2 | 55-90 |
| 9.5 | 1292 | 3974 | 39.7 | 60.3 | 35-65 |
| 4.75 | 1490 | 5464 | 54.6 | 45.4 | 25-55 |
| 2.36 | 2456 | 7920 | 79.2 | 20.8 | 20-40 |
| 0.425 | 1020 | 8940 | 89.4 | 10.6 | 10-25 |
| 0.075 | 659 | 9599 | 96.0 | 4.0 | 0-5 |

**TESTS ON FILLER SCREEN MATERIALS**

| Sl no | Particulars | Test results | Spec.Limit Vide Table |
|---|---|---|---|
| 1 | Liquid Limit, % | 21.33% | Maximum 25 |
| 2 | Plasticity index, % | Non plastic | Maximum 6 |

* The results obtained are satisfactory as per standard requirements.

ಸಹಾಯಕ ಅಭಿಯಂತರರು

FOR CIVIL Pro.

Sig.....R'KARTHIK RECHAN

Date.....Authorized Signatory

Quality Manager

Page 1/1

*End of Report*

Assistant Executive Engineer
B.B.M.P. Byatarayanapura Sub Division
Bangalore-560 024

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com



Scanned with CamScanner

CIVIL PRO
AN ISO 9001 : 2008 COMPANY & ACCREDITED LABORATORY AS PER ISO/IEC 17025:2017
# 4, 7TH MAIN MALLESWARAM, BANGALORE -3
Certificate No.: TC-5548

# TEST RESULTS OF GRADATION FOR GSB
## (IS 2386:(Part 1) 1963 (RA2011)

Lab ID : CP-RW-2022-07-01-01 Date: 26-05-2022

Project Name : Improvements to Roads and Drains at Bharathnagara, Sadiq Layout, Anjanadru Layout Balance Roads and Surrounding Area in Ward No. 06 Byatarayanapura Sub Division

Agency : Sri. K Lakshmi Narayana Reddy, No:688, 1st Floor, Vyalikaval Society, Near Chaitanya School, Veeranapalya, Bangalore-560045.

Customer Reference : BBMP/EE/BTP/WO/01/2021-22

Date of Receipt : 24-05-2022

Type of Mix : GSB (Granular Sub Base)

Date of test : 24-05-2022

Oven Dry Weight : 10000 Grams

| IS Sieve Size(mm) | Weight Retained (gm) | Cumulative Weight Retained (gm) | % Cumulative Weight Retained | % Passing | Spec. Limit Vide Table 400.1 MORTH Specification |
|---|---|---|---|---|---|
| 75 | 0 | 0 | 0.0 | 100.0 | 100 |
| 53 | 996 | 996 | 10.0 | 90.0 | 80-100 |
| 26.5 | 1689 | 2685 | 26.9 | 73.2 | 55-90 |
| 9.5 | 1296 | 3981 | 39.8 | 60.2 | 35-65 |
| 4.75 | 1493 | 5474 | 54.7 | 45.3 | 25-55 |
| 2.36 | 1769 | 7243 | 72.4 | 27.6 | 20-40 |
| 0.425 | 1659 | 8902 | 89.0 | 11.0 | 10-25 |
| 0.075 | 1098 | 10000 | 100.0 | 0.0 | 0-5 |

**TESTS ON FILLER SCREEN MATERIALS**

| Sl no | Particulars | Test results | Spec.Limit Vide Table |
|---|---|---|---|
| 1 | Liquid Limit, % | 22.53% | Maximum 25 |
| 2 | Plasticity index, % | Non plastic | Maximum 6 |

* The results obtained are satisfactory as per standard requirements.

FOR CIVIL Pro.
R KARTHIK RECHAN
Authorized Signatory
Quality Manager

Page 1/1
*End of Report*

Assistant Executive Engineer
B.B.M.P.

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com



Scanned with CamScanner

CIVIL PRO
AN ISO 9001 : 2008 COMPANY & ACCREDITED LABORATORY AS PER ISO/IEC 17025:2017
# 4, 7TH MAIN MALLESWARAM, BANGALORE -3
Certificate No.: TC-5548

# TEST RESULTS OF GRADATION FOR GSB
## (IS 2386:(Part 1) 1963 (RA2011)

Lab ID : CP-RW-2022-07-01-01 Date: 26-05-2022

Project Name : Improvements to Roads and Drains at Bharathnagara, Sadiq Layout, Anjanadru Layout Balance Roads and Surrounding Area in Ward No. 06 Byatarayanapura Sub Division

Agency : Sri. K Lakshmi Narayana Reddy, No:688, 1st Floor, Vyalikaval Society, Near Chaitanya School, Veeranapalya, Bangalore-560045.

Customer Reference : BBMP/EE/BTP/WO/01/2021-22

Date of Receipt : 24-05-2022

Type of Mix : GSB (Granular Sub Base)

Date of test : 24-05-2022

Oven Dry Weight : 10000 Grams

| IS Sieve Size(mm) | Weight Retained (gm) | Cumulative Weight Retained (gm) | % Cumulative Weight Retained | % Passing | Spec. Limit Vide Table 400.1 MORTH Specification |
|---|---|---|---|---|---|
| 75 | 0 | 0 | 0.0 | 100.0 | 100 |
| 53 | 391 | 391 | 3.9 | 96.1 | 80-100 |
| 26.5 | 1801 | 2192 | 21.9 | 78.1 | 55-90 |
| 9.5 | 2911 | 5103 | 51.0 | 49.0 | 35-65 |
| 4.75 | 1601 | 6704 | 67.0 | 33.0 | 25-55 |
| 2.36 | 1563 | 8267 | 82.7 | 17.3 | 20-40 |
| 0.425 | 536 | 8803 | 88.0 | 12.0 | 10-25 |
| 0.075 | 956 | 9759 | 97.6 | 2.4 | 0-5 |

**TESTS ON FILLER SCREEN MATERIALS**

| Sl no | Particulars | Test results | Spec.Limit Vide Table |
|---|---|---|---|
| 1 | Liquid Limit, % | 23.56% | Maximum 25 |
| 2 | Plasticity index, % | Non plastic | Maximum 6 |

* The results obtained are satisfactory as per standard requirements.

FOR CIVIL Pro.

Sig.....R.KARTHIK RECHAN
Date.....Authorized Signatory
Quality Manager

CIVIL Pro BANGALORE

Assistant Executive Engineer
Byatarayanapura Sub Division
B.B.M.P. Bangalore-560024

Page 1/1
*End of Report*



Scanned with CamScanner